

The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date of well completion.

RECEIVED Klamath 14900 RECEIVED  
 FACTOR SEP 16 1966 WATER WELL REPORT NOV 10 1966  
 N 97310 STATE OF OREGON State Well  
 STATE ENGINEER Please type or print STATE ENGINEER State Th  
 OREGON

NOV 10 1966  
Sta

State, We have

State Permit No.

Name Weyerhaeuser Company  
Address P.O. Box 9  
Klamath Falls, Oregon

County Klamath Driller's well number \_\_\_\_\_  
SE 1/4 NE 1/4 Section 25 T. 40S R. 15E, W.M.  
 Bearing and distance from section or subdivision corner \_\_\_\_\_

Bearing and distance from section or subdivision corner

N 57°10' W - 1060.31 feet from  
east 1/4 Corner sec. 25, T40S, R15E, WM

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐  
 12. If not a new well, comment, describe material and procedure in Item 12.

Domestic ☒ Industrial ☒ Municipal ☐  
Irrigation ☐ Test Well ☐ Other ☐

Rotary	<input type="checkbox"/>	Driven	<input type="checkbox"/>
Cable	<input checked="" type="checkbox"/>	Jetted	<input type="checkbox"/>
Dug	<input type="checkbox"/>	Bored	<input type="checkbox"/>

(6) CASING INSTALLED: Threaded ☐ Welded ☒  
80 " Diam. from 0 ft. to 180 ft. Gage 1250  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
 " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

Perforated? ☒ Yes ☐ No

Type of perforator used

Size of perforations	in. by	in.
perforations from		ft. to
perforations from		ft. to
perforations from		ft. to
perforations from		ft. to
perforations from		ft. to

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type \_\_\_\_\_ Model No. \_\_\_\_\_

\_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Well seal—Material used in seal Cement  
Depth of seal 40 ft. Was a packer used? yes  
Diameter of well bore to bottom of seal 12 in.  
Were any loose strata cemented off? ☐ Yes ☒ No Depth \_\_\_\_\_  
Was a drive shoe used? ☒ Yes ☐ No  
Was well gravel packed? ☐ Yes ☒ No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusable water? ☐ Yes ☒ No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

Static level 28 ft. below land surface Date May 16  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? Intersate

Yield: 500 gal./min. with 30 ft. drawdown after 8 hrs

" " " "

33 33 33 33

Bailer test	gal./min. with	ft. drawdown after	hrs
-------------	----------------	--------------------	-----

Artesian flow g.p.m. Date

Temperature of water 58 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well below casing 10

(12) WELL LOG: Diameter of well below casing .....

Depth drilled 592 ft. Depth of completed well 592 ft.

**Formation:** Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation

MATERIAL	FROM	TO
rock formation,	0	592
this well was all rock formation with little change.		

Work started Feb 1966 Completed May 1966  
Date well drilling machine moved off of well Mar. 16 1966

Manufacturer's Name J. Johnson  
Type: Pusher H.P. 30

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W. L. Hartley, Jr.  
(Person, firm or corporation) (Type or print)

Address Bernanza One

Drilling Machine Operator's License No. 1,20

[Signed] G. Robert L. Nantley  
(Water Well Contractor)

Contractor's License No. 164 Date May 16, 196

(USE ADDITIONAL SHEETS IF NECESSARY)