NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
MAY 8 - 1972
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

4PM
14928

State Well No. 41/10-4 bb
State Permit No.

(1) OWNER:
Name William L. Garriatt
Address 111 Sheldon Street
Klamath Falls, Oregon

(2) TYPE OF WORK (check):
New Well XX Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
12" Diam. from 0 ft. to 20 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 40 gal./min. with 0 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 0 - 20 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 2 sacks
Number of sacks of bentonite used in well seal 2 sacks
Brand name of bentonite Big Horn
Number of pounds of bentonite per 100 gallons of water 100 lbs./100 gals.
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Klamath Driller's well number
NW ¼ NW ¼ Section 4 T. 41S R. 10E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 125 ft.
Static level 118 ft. below land surface. Date 4/7/72
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 12"
Depth drilled 210 ft. Depth of completed well 210 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Light Clay	0	20'	
Light Green Clay	20	45	
Dark Green Clay	45	52	
(with some cinders)			
Cinders and Clay	52	120	
Cinders and Gravel	120	176	
Black Lava Rock	176	191	
Black Lava Rock (Med.Hard)	191	198	
Gray Rock (Hard)	198	210	

Work started 3/23 1972 Completed 4/11/ 1972
Date well drilling machine moved off of well 4/11 1972

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Carl V. Enloe (Drilling Machine Operator) Date 5/3, 1972
Drilling Machine Operator's License No. 342

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name C&C Enloe Well Drilling (Person, firm or corporation) (Type or print)
Address P.O. Box 323 Dorris, Calif. 96023
[Signed] Carl V. Enloe (Water Well Contractor)
Contractor's License No. 503 Date 5/3, 1972

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119