

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

RECEIVED

MAY 29 1967

STATE OF OREGON (Please type or print)

ENGINEER G-3978

State Well No. 41/10-4 N

State Permit No.

(1) OWNER:

Name GEO. Burrell Address 1379 Brookdale Medford Oreg.

(2) LOCATION OF WELL:

County Klamath Driller's well number SW 1/4 SW 1/4 Section 4 T. 41S R. 10E W.M. Bearing and distance from section or subdivision corner near NORTH EAST CORNER

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

14" Diam. from T.R. ft. to 20 ft. Gage 250

(7) PERFORATIONS:

Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal cement Depth of seal 20 ft. Was a packer used? no Diameter of well bore to bottom of seal 22" in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [x] Yes [] No Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 118 ft. below land surface Date 5-20-67 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No If yes, by whom? VALLEY PUMP Yield: 1100 gal./min. with 72 ft. drawdown after 12 hrs.

(12) WELL LOG:

Diameter of well below casing 14" Depth drilled 853 ft. Depth of completed well 853' ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Rows include: white chert, sandstone, white chert, blue chert, white chert, cemented gravel, hard rock, soft rock, hard rock, soft rock, hard rock, green shale, hard shale, hard siliceous like material, rock (soft), hard rock, hard black shale, hard rock, hard blue clay, hard rock, hard shale, rock (soft), hard rock, hard sticky blue clay.

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Owen Storey (Person, firm or corporation) (Type or print) Address Box 347 - Davis, Calif. Drilling Machine Operator's License No. 111 [Signed] Owen Storey (Water Well Contractor) Contractor's License No. 94 Date 5-23, 1967

WATER WELL REPORT

STATE OF OREGON (Please type or print)

G-3978

State Well No. 41/10-4N State Permit No.

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

(1) OWNER:

Name Geo. Burrell Address 1379 Brookdale Medford, Oreg.

(2) LOCATION OF WELL:

County Klamath Driller's well number SW 1/4 SW 1/4 Section 4 T. 41 S R. 10 E W.M. Bearing and distance from section or subdivision corner N. E. Corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:

Threaded Welded Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Depth of seal ft. Was a packer used? Diameter of well bore to bottom of seal in. Were any loose strata cemented off? Yes No Depth Was a drive shoe used? Yes No Was well gravel packed? Yes No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? Yes No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level ft. below land surface Date Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? Yes No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing Depth drilled ft. Depth of completed well ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include Haul Rock, Hard shale, Hard Rock, Hard Sticky shale, Shale, Hard Rocks, Clay with show of pumice, Hard Rock, Chippy shale, Heavy green chert, Hard Sticky shale, Extra Hard Rock, Sticky shale, Hard Rock, Seat Rock, Hard Rock, Extra Hard Rock, Hard Sticky shale, Hard Rock, Shale, Hard Rocks, Hard Sticky shale.

Work started 3-2 1967 Completed 5-15 1967 Date well drilling machine moved off of well 5-20 1967

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME OREN STOREY (Person, firm or corporation) (Type or print) Address Box 347 - Davis, Calif. Drilling Machine Operator's License No. 111 [Signed] Oren Storey (Water Well Contractor) Contractor's License No. 94 Date 5-23 1967

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

KLAM 14931

WATER WELL REPORT

STATE OF OREGON (Please type or print)

G-3978

State Well No.

41/10-4N

State Permit No.

(1) OWNER:

Name Geo. Burrell
Address 1379 Brookdale Medford Oreg.

(2) LOCATION OF WELL:

County Klamath Driller's well number
BW 1/4 SW 1/4 Section 4 T. 41S R. 10E W.M.
Bearing and distance from section or subdivision corner
NE CORNER

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other
Rotary Cable Dug Driven Jetted Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded Welded

" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used
Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal
Depth of seal ft. Was a packer used?
Diameter of well bore to bottom of seal in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level ft. below land surface Date
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing

Depth drilled 853 ft. Depth of completed well 853 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO	
<u>cemented gravel</u>	<u>801</u>	<u>810</u>	
<u>extra hard rock</u>	<u>810</u>	<u>825</u>	<u>15'</u>
<u>stony shale</u>	<u>825</u>	<u>829</u>	
<u>hard rock</u>	<u>829</u>	<u>853</u>	<u>24</u>
<u>Well was tested at 658' but had only 300 gal per m.</u>			
<u>Tested at 853' and came in at 1100 gal per m.</u>			
<u>lost cuttings between 837 and 853.</u>			

Work started 3-2 1967 Completed 5-15 1967
Date well drilling machine moved off of well 5-20 1967

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME OREN STOREY (Person, firm or corporation) (Type or print)
Address Box 849 - Dallas, Calif
Drilling Machine Operator's License No. 111
[Signed] Oren Storey (Water Well Contractor)
Contractor's License No. 74 Date 5-23 1967