STATE ENGINEER Salem, Oregon	kuam 15095	Well Record	COUNTY	NO. 41/12-15F2 Klamath N NO
OWNER: Town	n of Malin	MAILING ADDRESS:	•	
		CITY AND STATE:		
	N	E.		
	T S., R	w., ww.		
Bearing and distance f				
corner				

Altitude at well	4,066			
TYPE OF WELL:D	rilled Date Constr	ructed		
Depth drilled 327	Depth cased		Section	
CASING RECORD: 10-8 inc	eh			
FINISH:			:	
AQUIFERS:				
•	d gravel (?)			
	below land surface			
PUMPING EQUIPM Capacity600	ENT: TypeTurb G.P.M.	ine		H.P
WELL TESTS:	ft ofter	hours		G.P.M.
		hours		
USE OF WATER	Public Supply	Temp.	°F.	, 19

City Well No. 2; located 300 ft. west of well No. 1; drawdown 10 ft. when pumped at 532 gpm for l_hr.

Log Water Level Measurements Chemical Analysis Aquifer Test

ADDITIONAL DATA:

REMARKS: