

KLAM 1625

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

KLAM 1625

State Well No. 35/12-27R

State Permit No. _____

(1) OWNER:

Name Dallas G. Givins
Address Rt 1 Box 618
Klamath Falls, Oregon

(2) LOCATION OF WELL:

County Klamath Driller's well number _____
NE 1/4 SE 1/4 Section 27 T. 35 S R. 12 E W.M.
Bearing and distance from section or subdivision corner 1,340 ft.
N. and 680 ft. W. from SE corner of S. 27

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded Welded
12" Diam. from 0 ft. to 80 ft. Gage 250
" Diam. from " ft. to " ft. Gage _____
" Diam. from " ft. to " ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
Size of perforations in. by in.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Diam. Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:

Well seal—Material used in seal cement
Depth of seal 80 ft. Was a packer used? no
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from " ft. to " ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 0 ft. below land surface Date _____
Artesian pressure 3 lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 840 gal./min. with 80 ft. drawdown after 1/2 hrs.
" 840 " 80 " 1 1/2 hrs.
" " " " "
Ballor test gal./min. with ft. drawdown after hrs.
Artesian flow 240 g.p.m. Date June 6, 1962
Temperature of water 52 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 720 ft. Depth of completed well 720 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soil	0	5
Chalk white	5	30
Grey sand	30	35
white chalk	35	100
clay blue w/seams of sand	100	200
Semi hard sand w/ gravel	200	250
Light brown clay	250	300
cynders black (water)	300	340
clay blue grey w/ seams of pumic	340	400
cynders red (water)	400	420
Blue grey clay w/ sand strata	420	580
Light gravel dark in color	580	590
Clay blue	590	600
Sand stone grey	600	650
Semi hard sand (water)	650	675
Clay blue	675	700
Sand gravel & clay	700	720

Work started Sept. 1 19 61 Completed May 9 19 62
Date well drilling machine moved off of well May 9 19 62

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Dallas G. Givins
(Person, firm or corporation) (Type or print)

Address Rt. 1 Box 618

Drilling Machine Operator's License No. _____

[Signed] Dallas G. Givins
(Water Well Contractor)

Contractor's License No. _____ Date Jan. 29, 1963