# WATER WELL REPORT
STATE OF OREGON

RECEIVED
OCT 5 1984
WATER RESOURCES DEPT
SALEM, OREGON

KLAM 1736

State Well No. 36S/6E-36d

State Permit No. .....

## (1) OWNER:
Name ROBERT SLOAN
Address BOX 79, HARRIMAN RT
City KLAMATH FALLS, State ORE

## (2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

## (3) TYPE OF WELL:
Rotary Air [X] Driven [ ]
Rotary Mud [ ] Dug [ ]
Cable [ ] Bored [ ]

## (4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]
Thermal: [ ] Withdrawal [ ] Reinjection [ ]

## (5) CASING INSTALLED:
Steel [X] Threaded [ ] Plastic [ ] Welded [X]
6 5/8" Diam. from +1 ft. to 68 ft. Gauge 250
..... Diam. from ..... ft. to ..... ft. Gauge .....

## LINER INSTALLED:
..... Diam. from ..... ft. to ..... ft. Gauge .....

## (6) PERFORATIONS:
Perforated? [X] Yes [ ] No
Type of perforator used FACTORY
Size of perforations 1/8 in. by 3 in.
228 perforations from 48 ft. to 68 ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

## (7) SCREENS:
Well screen installed? [ ] Yes [X] No
Manufacturer's Name .....
Type ..... Model No. .....
Diam. ..... Slot Size ..... Set from ..... ft. to ..... ft.
Diam. ..... Slot Size ..... Set from ..... ft. to ..... ft.

## (8) WELL TESTS:
Drawdown is amount water level is lowered below static level

Was a pump test made? [ ] Yes [X] No If yes, by whom?
Yield: ..... gal./min. with ..... ft. drawdown after ..... hrs.
" ..... " ..... " .....
Air test 100 gal./min. with drill stem at 65 ft. 2 hrs.
Bailer test ..... gal./min. with ..... ft. drawdown after ..... hrs.
Artesian flow ..... g.p.m.
Temperature of water 43 Depth artesian flow encountered ..... ft.

## (9) CONSTRUCTION:
Special standards: Yes [ ] No [X]
Well seal—Material used CEMENT
Well sealed from land surface to 40 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 10 sacks
How was cement grout placed? Pumped
.....
.....
Was pump installed? NO Type ..... HP ..... Depth ..... ft.
Was a drive shoe used? [X] Yes [ ] No Plugs ..... Size: location ..... ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of Water? ..... depth of strata .....
Method of sealing strata off .....
Was well gravel packed? [ ] Yes [X] No Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

## (10) LOCATION OF WELL:
County KLAMATH Driller's well number
SE ¼ NW ¼ Section 3 T. 36S R. 6E W.M.
Tax Lot # ..... Lot ..... Blk ..... Subdivision .....
Address at well location: .....

## (11) WATER LEVEL: Completed well.
Depth at which water was first found 60 ft.
Static level 39 ft. below land surface. Date 9/21/84
Artesian pressure ..... lbs. per square inch. Date .....

## (12) WELL LOG:
Diameter of well below casing .....
Depth drilled 68 ft. Depth of completed well 68 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

| MATERIAL | From | To | SWL |
|---|---|---|---|
| GRAY BASALT | 0 | 60 | |
| Red CINDERS | 60 | 68 | |

Work started 9/17/84 19 Completed 9/21/84 19
Date well drilling machine moved off of well 9/21/84 19

### Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Max Matthason (Drilling Machine Operator) Date 10-3, 1984
Drilling Machine Operator's License No. 1213

### Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name E.E. STONEY & SON WELL DRILLING INC (Person, firm or corporation) (Type or print)
Address 3847 HOPE K FALLS, ORE
[Signed] E.E. Stoney (Water Well Contractor)
Contractor's License No. 74 Date 10/1/84, 19

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*12658-690