## WATER WELL REPORT STATE OF OREGON

WATER RESOURT WATER RESOURCES DEPT Permit No. SALEM. OREGON

(1) OWNER:	(10) LOCATION OF WELL:		
Name Mountain Lakes Bible Camp	County Klamath Driller's well number		
Address 2244 Wiard St.	S <sup>1</sup> / <sub>2</sub>	R. 6 E.	W.M.
City Klamath Falls, State OR.97601	Tax Lot # Lot Blk	Subdivisio	n
(2) TYPE OF WORK (check):	Address at well location: Mountain Lakes	Bible Camp	)
New Well □ Deepening ☒ Reconditioning □ Abandon □	Rocky Point, OR.		
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	ell.	
	Depth at which water was first found	400	ft.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 312 ft. below l	and surface. Date	8,7,81
Rotary Air Driven Domestic Line Industrial Municipal Rotary Mud Dug Direction Test Well Dother D		er square inch. Dat	
Cable Bored Thermal: Withdrawal Reinjection	(12) WELL LOG: Diameter of well below	casing 6inch	L
CASING INSTALLED: Steel  Plastic *		-	460 ft.
ready installed. Steel   Plastic & Welded	Formation: Describe color, texture, grain size and stru		
"Diam. from	thickness and nature of each stratum and aquifer pene for each change of formation. Report each change in		
ft. Gauge	and indicate principal water-bearing strata.	,	
LINER INSTALLED: PVC	MATERIAL	From To	SWL
4 "Diam from 0 ft to 460 ft Gauge Class 160	Rock in the hole at 123'		
(6) PERFORATIONS: Skill Perforated? ②Yes □ No Type of perforator used	Cement	233 270	
Size of perforations 1/8 in. by 6 in.	Red lava, hard	270 275	
64 perforations from 420 ft. to 460 ft	Black basalt rock	275   303	
perforations from ft. to ft.	Fractured black basalt rock	303 310	
perforations from	Black basalt rock	310 335	
	Fractured basalt & layers of	335	
(7) SCREENS: Well screen installed? ☐ Yes ☑ No	red lava	355	
Manufacturer's Name NONE	Black basalt rock	355 370	
Type	Fractured basalt & red lava	370 400	
Diam. Slot Size Set from ft. to ft.	Soft cinders and red clay	400 420	312
Diam. Slot Size Set from ft. to ft.  Drawdown is amount water level is lowered	Black basalt rock	420 450	
(8) WELL TESTS:  below static level	creviced from 430'	450 460	2121
Was a pump test made? □ Yes ⊀ No If yes, by whom?	Black basalt, very hard.	450 460	312'
eld: gal./min. with ft. drawdown after hrs.			
" " " "			
Trest 15 gal./min. with drill stem at 425 ft. 1 hrs.			
Bailer test gal./min. with ft. drawdown after hrs.			
*rtesian flow g.p.m.			
mperature of water 49 Depth artesian flow encountered ft.	Work started 8,4, 1981 Complete	ed 8,7,	1981
CONSTRUCTION: Special standards: Yes  No	Date well drilling machine moved off of well	8,7,	1981
Well seal—Material used Already installed & sealed.	Drilling Machine Operator's Certification:		
Well sealed from land surface to	This well was constructed under my direct s	unerwision Mate	eriala used
Diameter of well bore to bottom of seal in.	and information reported above pro-true to my b	knowledge a	nd belief.
Diameter of well bore below sealin.	[Signed] LW July	Date	12,79.81
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No	<b>13</b> 88	
How was cement grout placed?	17		
	Water Well Contractor's Certification:		
No	This well was drilled under my jurisdiction the best of my knowledge and belief.	and this report	is true to
Was pump installed?	Name Norm Sevey Well Drilling.	Inc.	
Was a drive shoe used? ☐ Yes ▼ No Plugs Size: location ft.	(Person, firm or corporation)	(Туре от	
Did any strata contain unusable water?   Yes  No  Type of Water?  DODG	Address 800 Old Midland Rd Klam	ath Falls,	UK • 9.760
Type of Water? NONE depth of strata  Method of sealing strata off	[Signed] /any Seve	•/	
Was well gravel packed? ☐ Yes X No Size of gravel:	Water Well Contract	<b>新</b> . 12.	81
Gravel placed from	Contractor's License No		, 19.5