

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

KLAMATH 19

RECEIVED APR 4 1967

WATER WELL REPORT OF STATE ENGINEER State Well No. 23/6-23
STATE OF OREGON SALEM, OREGON
 (Please type or print) State Permit No. _____

(1) OWNER:

Name Dept. of Agriculture-Forest Service
 Address Deschutes National Forest
Bend, Oregon.

(2) LOCATION OF WELL:

County Klamath Driller's well number 265
 1/4 Section 23 T. 23S R. 6E W.M.
 Bearing and distance from section or subdivision corner
Sunset Cove Campground

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other
Recreational

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
 " Diam. from _____ ft. to _____ ft. Gage _____
8 1/2" Diam. from 0 ft. to 20 ft. Gage .277
6" Diam. from 16 ft. to 181 ft. Gage .280

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used Acetelyne Torch
 Size of perforations _____ in. by _____ in.
 _____ perforations from _____ ft. to _____ ft.
88 perforations from 159 ft. to 181 ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____ Model No. _____
 _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
 Depth of seal 20 ft. Was a packer used? no
 Diameter of well bore to bottom of seal 16 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 132 ft. below land surface Date 3-3-67
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? Driller
 Yield: 50 gal./min. with no ft. drawdown after 5 hrs.
 " " " " " "
 " " " " " "
 Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow g.p.m. Date _____
 Temperature of water 40 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8
 Depth drilled 181 ft. Depth of completed well 181 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Pumice-Yellow-Brown Ssf.</u>	<u>0</u>	<u>7</u>
<u>Sand & Gravel-Medium</u>	<u>7</u>	<u>12</u>
<u>Basalt-Hard Grey</u>	<u>12</u>	<u>21</u>
<u>Red Cinders-Semi-hard</u>	<u>21</u>	<u>52</u>
<u>Basalt-Hard</u>	<u>52</u>	<u>59</u>
<u>Red Cinders-Semi-hard</u>	<u>59</u>	<u>181</u>

Work started 2-2-67 19 Completed 3-4-67 19
 Date well drilling machine moved off of well 3-5-67 19

(13) PUMP:

Manufacturer's Name _____ Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME CULLETT BROTHERS
(Person, Firm, or Corporation) (Type or print)
 Address Route 1-Myrtle Creek, Ora.

Drilling Machine Operator's License No. 288
 [Signed] _____ (Water Well Contractor)
 Contractor's License No. 252 Date 3-1-67, 19____

(USE ADDITIONAL SHEETS IF NECESSARY)