

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

# WATER WELL REPORT RECEIVED

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

STATE OF OREGON JUN 23 1975 State Well No. 365/11E-2388  
(Please type or print) STATE ENGINEER State Permit No. KLAM 2001  
(Do not write above this line) SALEM, OREGON

Application  
6-7-75

**(1) OWNER:**

Name EDWIN K VIEIRA  
Address STAR RT BOX 6 BEATTY, ORE

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:** (4) **PROPOSED USE (check):**

Rotary  Driven  Domestic  Industrial  Municipal   
Cable  Jetted  Irrigation  Test Well  Other   
Dug  Bored

**CASING INSTALLED:** Threaded  Welded

" Diam. from ..... ft. to ..... ft. Gage .....  
8 5/8" Diam. from 0 1/2 ft. to 20 1/2 ft. Gage 25.0  
" Diam. from ..... ft. to ..... ft. Gage .....

**PERFORATIONS:** Perforated?  Yes  No.

Type of perforator used .....  
Size of perforations in. by ..... in.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.  
..... perforations from ..... ft. to ..... ft.

**(7) SCREENS:** Well screen installed?  Yes  No

Manufacturer's Name .....  
Type ..... Model No. ....  
Diam. .... Slot size ..... Set from ..... ft. to ..... ft.  
Diam. .... Slot size ..... Set from ..... ft. to ..... ft.

**(8) WELL TESTS:** Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
175 " @ 40 " 1/2 "  
300 " @ 50 " 1/2 "  
500 " @ 117 " 1 "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. ....

Temperature of water 53 Depth artesian flow encountered ..... ft.

**(9) CONSTRUCTION:**

Well seal—Material used Cement  
Well sealed from land surface to 20 ft.  
Diameter of well bore to bottom of seal 13 1/4 in.  
Diameter of well bore below seal ..... in.  
Number of sacks of cement used in well seal 5 sacks  
Number of sacks of bentonite used in well seal ..... sacks  
Brand name of bentonite .....  
Number of pounds of bentonite per 100 gallons  
of water ..... lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs ..... Size: location ..... ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? ..... depth of strata .....  
Method of sealing strata off .....  
Was well gravel packed?  Yes  No Size of gravel: .....  
Gravel placed from ..... ft. to ..... ft.

**(10) LOCATION OF WELL:**

County KLAMATH Driller's well number .....  
SE 1/4 SE 1/4 Section 23 T. 36S R. 11E W.M.  
Bearing and distance from section or subdivision corner .....

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found ..... ft.  
Static level 14 ft. below land surface. Date 6/10/75  
Artesian pressure ..... lbs. per square inch. Date .....

**(12) WELL LOG:** Diameter of well below casing 7 9/8

Depth drilled 117 ft. Depth of completed well 117 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SANDY TOPSOIL	0	2	
BROWN CHALK ROCK	2	6	
BLACK SANDSTONE	6	10	
BROWN SHALE	10	30	
WHITE PONICE	30	32	
YELLOW SHALE	32	38	
BLACK SANDSTONE	38	66	WB
YELLOW SHALE	66	70	
GREY SHALE & STREAKS BLACK SANDSTONE	70	73	
YELLOW SHALE	73	105	
BLACK SANDSTONE & STREAKS	105		
grey shale		117	WB

Work started 6/9/75 19 Completed 6/10/75 19  
Date well drilling machine moved off of well 6/10/75 19

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] David M. Storey Date 6/17, 1975  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 656

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name E. E. Storey & Son Well Drilling Inc.  
(Person, firm or corporation) 3547 Hope Street (Type or print)  
Address Klamath Falls, Oregon 97601  
[Signed] E. E. Storey Pres  
(Water Well Contractor)  
Contractor's License No. 74 Date 6/17/75, 1975