NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Permit No.

(1) OWNER:	(10) LOCATION OF WELL:			
NameSteve Harris	County Klamath Driller's well number			
Address Star Rt. #2	NE 14 NE 14 Section 26 T. 36 S R. 11 E W.M.			
Sprague River, Oregon 97639	Bearing and distance from section or subdivision corner			
(2) TYPE OF WORK (check):				· · · · · · · · · · · · · · · · · · ·
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐				
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	ell.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 70 ft.			
Rotary Driven Domestic M Industrial Municipal				
d Setted L				20-00
Bored Irrigation Test Well Other	Artesian pressure lbs. per squar	e inch.	Date	
(5) CASING INSTALLED: Threaded [] Welded [(12) WELL LOG: Diameter of well h	_	•	8"
8" Diam. from	Diameter of well b			
" Diam. from ft. to ft. Gage	Depth drilled 140 ft. Depth of comple			40 ft.
" Diam. fromft. toft. Gage	Formation: Describe color, texture, grain size a and show thickness and nature of each stratum	ind struc m and a	ture of a	materials;
(A) DIDEON A MYONG	with at least one entry for each change of format	tion. Repo	ort each	change in
(6) PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate prin	cipal wa	ter-beari	ng strata.
Type of perforator used	MATERIAL	From	То	swL
Size of perforations in. by in.	Top Soil	0	3	
perforations from ft. to ft.	Sandy Brown Clay	3	25	
perforations from ft. to ft.	Brown Clay	25	27	
perforations from	Sand Rock	27	46	
(E) COREENS	Brown Clay	46	55	
(7) SCREENS: Well screen installed? Yes No	White Broken Rock	55	72	40'
Manufacturer's Name	Riolite Rock	72	105	
Type Model No.	White Riolite	105	114	
Diam. Slot size Set from ft. to ft.	Hard White Rock	114	134	
Diam Slot size Set from ft. to ft.	Brown & White Rock	134	140	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level		<u>-</u>		_
		n		
a pump test made? ⊠ Yes □ No If yes, by whom? <u>Driller</u>	RECEIVE	, U		
Yield: 300 gal./min. with 40 ft. drawdown after 1 hrs.	JUL 91980			
n " "				
,, ,, ,, ,, ,, ,, ,, ,, ,, ,, ,, ,, ,,	WATER RESOURCES	DEPT		
er test gal./min. with ft. drawdown after hrs,	SALEM, OREGO	4	-	
Artesian flow g.p.m.				
remperature of water 56 Depth artesian flow encountered ft.	Work started 5-27 1980 Complete	-	5-2	8 1980
	Date well drilling machine moved off of well	<u> </u>		8 1980
(9) CONSTRUCTION:	/			
Well seal—Material used Cement & 5% Bentonite Well sealed from land surface to 38 #	Drilling Machine Operator's Certification: This well was constructed under my	dinant	G11 m o m	
The state of the s	Materials used and information reported	above a	super are true	to my
Diameter of well bore to bottom of seal	best knowledge and belief.			
	[Signed] fly Machine Operator) Date 5-30, 1980			
Number of sacks of cement used in well sealsacks How was cement grout placed? Pumped from bottom of	Drilling Machine Operator's License No. 1388			
casing up to the ground surface.	The state of the state o			
	Water Well Contractor's Certification:			
	This well was drilled under my jurisdi	ction an	d this r	eport is
Was a drive shoe used? ☐ Yes 🏿 No Pluge Size: location ft.	true to the best of my knowledge and belief.			
Did any strata contain unusable water? Yes No	Name Norm Sevey Well Drilling, Inc. (Person, firm or corporation) (Type or print)			
Type of water? depth of strata	Address 5619 Leland Dr. Klamath Falls, OR 97601			
Method of sealing strata off			∺•••• 7tr	
	[Signed] (Water well Contre	in		
Was well gravel packed? ☐ Yes ☒ No Size of gravel:	i ,	<i></i>		
Gravel placed from ft. to ft.	Contractor's License No. 408 Date	<u> </u>	5 - 30	., 1980