

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write in this space)

RECEIVED KLAM 2014 365/11E-26.bc
OCT 2 1983
Permit No. #11 State level 9'
SALEM, OREGON

(1) OWNER:

Name Bob Hoffman
Address 933 Escondido Court-Alamo, CA 94507

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Liner
Threaded Welded
12 " Diam. from 280 ft. to 513 ft. Gage .325
12 " Diam. from 0 ft. to 280 ft. Gage .250
" Diam. from " ft. to " ft. Gage "

PERFORATIONS:

Perforated? Yes No.
Type of perforator used Mills Knife
Size of perforations 3/8 in. by 2 1/2 in.
480 perforations from 320 ft. to 496 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level.
Interstate Pump Co. Klamath Falls, OR
Was a pump test made? Yes No If yes, by whom?
Yield: 900 gal./min. with 140 ft. drawdown after 4 hrs.
" " " " " "
" " " " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal _____ in.
Diameter of well bore below seal _____ in.
Number of sacks of cement used in well seal 13 sacks
How was cement grout placed? Pump cement down between
16" casing & 12" casing liner - as per
instructions of Mr. Bob Kennedy
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number _____
SW 1/4 NW 1/4 Section 26 T. 36 R. 11 E W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 13 ft.
Static level _____ ft. below land surface. Date _____
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 12"
Depth drilled 634 ft. Depth of completed well 510 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Unknown	0	455	
Sand	455	510	
Basalt	510	634	
no water in bottom of well			

Work started 6/1 19 83 Completed 9/28 19 83
Date well drilling machine moved off of well 10/2 19 83

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Carl V. Enloe Date 10/9 19 83
(Drilling Machine Operator)

Drilling Machine Operator's License No. 316

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name C & C Enloe Drilling, Inc.
(Person, firm or corporation) (Type or print)
Address P.O. Box 323 Dorris, CA 96023

[Signed] Carl V. Enloe
(Water Well Contractor)

Contractor's License No. 503 Date 10/9 19 83