

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the
 STATE ENGINEER, SALEM 10, OREGON
 within 30 days from the date
 of well completion.

*KLAM
 2021*

WATER WELL REPORT
 STATE OF OREGON
 (Please type of year)

State Well No. 36/11-350
 State Permit No. _____

(1) OWNER:
 Name Mark Time Inc.
 Address Star Rt. Box 1
Beaty, Oregon

(2) LOCATION OF WELL:
 County Klamath Driller's well number _____
1/4 S.E. 1/4 Section 35 T. 36 R. 11 E W.M.
 Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):
 New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
 Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:
 Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED: Threaded Welded
16" Diam. from 0 ft. to 120 ft. Gage 250 W.
 _____" Diam. from _____ ft. to _____ ft. Gage _____
 _____" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
 Type of perforator used _____
 Size of perforations in. by _____ in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 _____ Slot size _____ Set from _____ ft. to _____ ft.
 _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
 Well seal—Material used in seal Drive shoe Driven in clay
 Depth of seal 120 ft. Was a packer used? No
 Diameter of well bore to bottom of seal 16 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:
 Static level 31 ft. below land surface Date 11/30/62
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? Valley Pump
 Yield: 3200 gal./min. with 90 ft. drawdown after 4 hrs.
 " " " "
 " " " "
 Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water 53 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 16'
 Depth drilled 384 ft. Depth of completed well 384 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Black Soil	0	4
Hard Pan	4	10
White chalk	10	30
Sandstone	30	45
Blue Clay	45	70
Gritty Blue Clay	70	112
Hard blue clay	112	125
Pumice Stone	125	131
Soft Black Sandstone	131	196
Packed Sand (sandstone)	196	199
Soft sandstone	199	214
Hard Black Sandstone	214	260
Hard Brown Sandstone	260	290
Yellow Clay containing Pumice	290	305
Yellow Clay With Gravel	305	318
Hard Gray Sandstone	318	326
Hard Cemented Gravel	326	328
Hard Gray Rock	328	347
Cemented Gravel	347	349
Loose Gravel	349	352
Extra Hard Black Rock	352	383
Loose Gravel With lots of water	383	384

Work started Nov. 1 19 62 Completed Nov. 30 19 62
 Date well drilling machine moved off of well Dec. 4 19 62

(13) PUMP:
 Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Oren L. Storey Welldrilling
 (Person, firm or corporation) (Type or print)
 Address Box 347 Dorris, Calif.
 Drilling Machine Operator's License No. 11
 [Signed] Oren Storey
 (Water Well Contractor)
 Contractor's License No. 194 Date Dec. 4, 19 62