

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED FEB 10 1963 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT

(Please type or print)

KLAM 2033

State Well No. 36/12-2D

State Permit No.

(1) OWNER:

Name L. L. Crawford  
Address Beatty Oregon

(2) LOCATION OF WELL:

County Klamath Driller's well number \_\_\_\_\_  
NW 1/4 NW 1/4 Section 2 T. 36 R. 12 W.M.  
Bearing and distance from section or subdivision corner  
800 ft east  
Madawa Spring  
road

(3) TYPE OF WORK (check):

Well  Deepening  Reconditioning  Abandon   
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
1 1/2" Diam. from 0 ft. to 15.0 ft. Gage 25-0  
1 1/2" Diam. from \_\_\_\_\_ ft. to 17.9 ft. Gage 25-0  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) SCREENS:

Well screen installed  Yes  No  
Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal cement  
Depth of seal 1.50 ft. Was a packer used? yes  
Diameter of well bore to bottom of seal 2.0 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(10) WATER LEVELS:

Static level \_\_\_\_\_ ft. below land surface Date \_\_\_\_\_  
Artesian pressure 3 lbs. per square inch Date Feb 15

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Drury Tate  
Yield: 2200 gal./min. with 70 ft. drawdown after 4 hrs.  
" " " " " "  
" " " " " "  
" " " " " "  
Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after 70 hrs.  
Artesian flow 600 g.p.m. Date Feb 15-63  
Temperature of water 60 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 5 1/2 - 5 3/4  
Depth drilled 1127 ft. Depth of completed well 1127 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
top soil	0	3
sandstone	3	8
chalk	8	140
sandstone	140	160
chalk	160	2434
white rock	434	1127

Work started 702 1961. Completed Feb 1963  
Date well drilling machine moved off of well Feb 20 1963

(13) PUMP:

Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W. L. Hartley & Sons  
(Person, firm or corporation) (Type or print)  
Address Bonanza Dr  
Drilling Machine Operator's License No. 120  
[Signed] Robert F Hartley  
(Water Well Contractor)  
Contractor's License No. 164 Date Feb 15, 1963