NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED JUN 30 1966 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

KLAM 2073 G6939 G-3471

State Well No. 36/12-16 Q

State Permit No.

(1) OWNER:
Name Bernard Heffer
Address Beatty Oregon

(2) LOCATION OF WELL:
County Klamath Driller's well number
SW ¼ SE ¼ Section 14 T. 36S R. 12E W.M.
Bearing and distance from section or subdivision corner
200 ft from corner

(3) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☑ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☐
12" Diam. from 0 ft. to 149 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☐ Yes ☑ No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Cement 6 sacks
Depth of seal 149 ft. Was a packer used?
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? ☑ Yes ☐ No Depth 60
Was a drive shoe used? ☑ Yes ☐ No
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusuable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level ft. below land surface Date
Artesian pressure 8 lbs. per square inch Date May 15 1965

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow 180 g.p.m. Date May 15
Temperature of water Was a chemical analysis made? ☐ Yes ☑ No

(12) WELL LOG: Diameter of well below casing 12
Depth drilled 524 ft. Depth of completed well 524 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
top soil	0	3
Chalk	3	104
Black sand	104	133
Chalk	133	420
rock	420	524

Work started April 10 1965 Completed May 15 1965
Date well drilling machine moved off of well 19

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME W. L. Hartley & Son (Person, firm or corporation) (Type or print)
Address Bonanza Ore
Drilling Machine Operator's License No. 120
[Signed] Robert J. Hartley (Water Well Contractor)
Contractor's License No. 164 Date June 29, 1965

(USE ADDITIONAL SHEETS IF NECESSARY)