

RECEIVED

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER

STATE OF OREGON (Please type or print)

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

HOMER DeLAMATER

MAY 25 1966 WATER WELL REPORT

KLAM 2081

State Well No. 36/12-22C

State Permit No.

G-3758

(1) OWNER:

Name HOMER DELMETER Address PO BOX 142 BEATH OREGON

(2) LOCATION OF WELL:

County SWMATH Driller's well number 0-1-0 SW 1/4 Section 15 T. 36 R. 5, 12 W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Rotary [] Driven [] Cable [X] Jetted [] Irrigation [X] Test Well [] Other [] Dug [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED:

12" Diam. from 14" ft. to 193" ft. Gage 250 Threaded [] Welded [X]

(7) PERFORATIONS:

Perforated? [] Yes [X] No Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed [] Yes [X] No Manufacturer's Name Model No. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal APPROX 5 YDS CEMENT. Depth of seal 190 ft. Was a packer used? Diameter of well bore to bottom of seal 16 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 212 ft. below land surface Date approx 4 May 23 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? VALLEY PUM Yield: 3500 gal./min. with 14 ft. drawdown after 2 hrs. Bailer test gal./min. with ft. drawdown after hrs. Artesian flow approx 900 g.p.m. Date May 22-66 Temperature of water Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 12" Depth drilled 300 ft. Depth of completed well 300 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation. MATERIAL FROM TO Sandy loam soil 0 3 Yellow shale 3 41 Grey clay 41 72 Yellow clay 72 115 Brown loam 115 135 Brown loam med. 135 136 Brown shale 136 167 Black sticky clay 167 205 Black loam 205 206 Black loam 206 213 Black loam 213 250 Red loam 250 270 Black loam 270 285 Blue gravel 285 295 Hard gravel 295 300 Artesian flow aquifer at 260-275

Work started April 12 1966 Completed May 16 1966 Date well drilling machine moved off of well May 26 1966

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME CHARLES E. HARTLEY (Person, firm or corporation) (Type or print) Address 4779 1/2 S. 6th ST B. KAN. ORE

Drilling Machine Operator's License No. 233

[Signed] Charles E. Hartley (Water Well Contractor)

Contractor's License No. 145 Date May 23, 1966