NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

KLAM 209

RECEIVED
AUG 3 1978
WATER RESOURCES DEPT.
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 23s/10E-27Cd

State Permit No.

(1) OWNER:
Name Bob Everly
Address Star Rt 1 Box 1061 La Pine, Ore 97739

(2) TYPE OF WORK (check):
New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [] Driven []
Cable [X] Jetted []
Dug [] Bored []

(4) PROPOSED USE (check):
Domestic [X] Industrial [] Municipal []
Irrigation [] Test Well [] Other []

(5) CASING INSTALLED:
Threaded [] Welded [X]
8" Diam. from +1 ft. to 19 ft. Gage .25
6" Diam. from 0 ft. to 60 ft. Gage .188
" Diam. from ft. to ft. Gage

PERFORATIONS:
Perforated? [X] Yes [] No
Type of perforator used Acetylene
Size of perforations 1/8" in. by 6 in.
perforations from 30 ft. to 50 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? [] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [] Yes [X] No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 30 gal./min. with 0 ft. drawdown after 1 hrs.
Artesian flow g.p.m.
Temperature of water 52° Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Portland Cement
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 7 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? [] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [X] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Klamath Driller's well number
SW ¼ SE ¼ Section 27 T. 23S R. 10E W.M.
Bearing and distance from section or subdivision corner
Tract 12+13 Split Rail Ranchos

(11) WATER LEVEL: Completed well.
Depth at which water was first found 35 ft.
Static level 35 ft. below land surface. Date 7-28-78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 8"
Depth drilled 60 ft. Depth of completed well 60 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Soil, Brown	0	6	
Clay, Green	6	30	
Pumice, white	30	33	
Sand, Course, Blk. wtr.	33	40	35
Clay, sandstone conglom	40	55	
Sand, Course	55	60	

Work started 7-21 1978 Completed 7-28 1978
Date well drilling machine moved off of well 7-28 1978

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Alvin Dehnunk (Drilling Machine Operator) Date 7-28, 1978
Drilling Machine Operator's License No. 960

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Dehnunk's Drilling Service (Person, firm or corporation) (Type or print)
Address 4911 SW Elkhorn, Redmond, Ore 97756
[Signed] Alvin Dehnunk (Water Well Contractor)
Contractor's License No. 627 Date 7-28, 1978

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119