

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion

KLAM 2150

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

Do not write above this line)

State Well No.

State Permit No.

RECEIVED JUL 11 1968 STATE ENGINEER SALEM, OREGON

KLAM 2150

36/14-29

G 5309

well #2

(1) OWNER:

Name CARSON P MERKLEY Address PO Box 63 BLY, ORE.

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(11) LOCATION OF WELL:

County Klamath Driller's well number SW 1/4 SE 1/4 Section 29 T. 36S R. 14E W.M. Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 18-16-12 Depth drilled 485 ft. Depth of completed well 485 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

CASING INSTALLED:

Threaded [] Welded [X]

18" Diam. from 7'1" ft. to 24' ft. Gage 250

PERFORATIONS:

Perforated? [] Yes [X] No

Type of perforator used

Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 42'6" ft. below land surface Date 7/3/68 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? PUMP CENTER

Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date

Temperature of water 58 Was a chemical analysis made? [] Yes [X] No

(10) CONSTRUCTION:

Well seal—Material used BENTONITE Depth of seal 23' Diameter of well bore to bottom of seal 22 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

Table with 4 columns: MATERIAL, From, To, SWL. Rows include Top Soil, BROWN LAVA, YELLOW ROCK, BLACK BASALT, CLAY BOUND GRAVEL, etc.

Work started 5/7/68 19 Completed 7/3/68 19 Date well drilling machine moved off of well 7/3/68 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Truman Morrison Date 7/9/68, 19 (Drilling Machine Operator)

Drilling Machine Operator's License No. 110

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME E E STOREY (Person, firm or corporation) (Type or print)

Address 3831 Hope Falls Ore

[Signed] E E Storey (Water Well Contractor)

Contractor's License No. 74 Date 7/9/68, 19