

RECEIVED
AUG 24 1959

STATE ENGINEER WATER WELL REPORT
SALEM, OREGON STATE OF OREGON

KLAM
218

23/10-28R

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

State Well No. 101
State Permit No. 1271

(1) OWNER:

Name Fred Farnsworth
Address Slope Oregon

(2) LOCATION OF WELL:

County KLAMATH Owner's number, if any—
SE 1/4 NE 1/4 Section 28 T. 23 R. 10E W.M.
Bearing and distance from section or subdivision corner
90 FEET 45° W QUARTER CORNER

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

NONE Threaded Welded
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used NONE
SIZE of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? Yes No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 5 FT. ft. below land surface Date AUG 15 57
Artesian pressure lbs. per square inch Date
Log Accepted by: Fred Farnsworth
[Signed] Date Aug 17, 1959
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? -SELF
Yield: 91 63/100 gal./min. with 7 1/2 ft. drawdown after 4 hrs.
IT WILL RUN 15 SPRINKLERS
AT 6 1/2 GAL PER MINUTE 4 HRS PER DAY
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 4 1/2 X 5 1/2 inches

Depth drilled ft. Depth of completed well 10 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>VOLCANIC ASH</u>	<u>SURFACE</u>	<u>6 FT</u>
<u>WATER SAND AND GRAVEL</u>	<u>6</u>	<u>8</u>
<u>HARD PAN</u>	<u>8</u>	<u>10</u>
<u>TO HARD FOR BULLDOZER TO CUT DEEPER</u>		
<u>15 SPRINKLERS THROWS GAL. 5498 PER HR.</u>		

Work started JULY 20 1959 Completed JULY 27 1959

(13) PUMP:

UNIT NO. 171648

Manufacturer's Name JACUZZI BROS
Type CENTRIFUGAL 1037BWZT H.P. 15-

Well Driller's Statement:

SPEC SB157

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME NONE
(Person, firm, or corporation) (Type or print)
Address
Driller's well number
[Signed] (Well Driller)
License No. Date, 19.....

WATER LEVEL