

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

KLAM 2245

RECEIVED
WATER WELL REPORT

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
APR 26 1979
(Please type or print)

*KLAM
2245*

State Well No. 375/9E-31CC
State Permit No. _____

WATER RESOURCES DEPT.
SALEM, OREGON
(Do not write above this line)

(1) OWNER:

Name Roy McCord
Address S. Rt. 5 Box 1140G
Klamath Falls Ore. 97601

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from +1 ft. to 87 ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used Mills Knife
Size of perforations in. by in.
80 perforations from 44 ft. to 87 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
" " " " " "
Baller test 40 gal./min. with 14 ft. drawdown after 1 hrs.
Artesian flow g.p.m. _____

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 30' ft.
Diameter of well bore to bottom of seal 10 1/2 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 31 sacks
How was cement grout placed? pumped from the bottom to land surface
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number _____
SW 1/4 SW 1/4 Section 31 T. 37S R. 9E W.M. _____
Bearing and distance from section or subdivision corner
NE Corner of Government Lot 3

(11) WATER LEVEL: Completed well.

Depth at which water was first found 30' ft.
Static level 11 ft. below land surface. Date 4-2-79
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 87' ft. Depth of completed well 87' ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top soil	0	3	
large cobbles + brown clay	3	12	
Brown Clay	12	19	
Blue Clay	12	30	
Red Cinders & gravel	30	87	11'

Work started 3-22 1979 Completed 4-2 1979
Date well drilling machine moved off of well 4-2 1979

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Roy W. Chancellor Date 4-13, 1979
(Drilling Machine Operator)
Drilling Machine Operator's License No. 1064

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Regen Chancellor Well-Drilling
(Person, firm or corporation) (Type or print)
Address P.O. Box 405 Keno, Ore. 97627
[Signed] Roy W. Chancellor
(Water Well Contractor)
Contractor's License No. 693 Date 4-13, 1979