NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

KLAM 2373 **WAREE WILL HIPORT

Please type or print)

WATER (RESOURCES DEPTE)

State Well No. 375/11/26-25td

State Permit No. G-8576

See mao in 5

SALEM, OREG	on see ma	o in
(1) OWNER:	(10) LOCATION OF WELL:	•
Name D& L LANCH	County KLAMATH Driller's well n	umber
Address 4231 BISBEE , SPACE 5	NW 4 NE 4 Section 25 T. 375	R. 11 5 F W.M.
KUMATH FAUS, OLEGOP	Bearing and distance from section or subdivis	
(2) TYPE OF WORK (check):	Dearing and distance from Section of Subdivisi	1011
New Well		, 1975 -
If abandonment, describe material and procedure in Item 12.	(11) WAMED LEVEL Constant	11
	(11) WATER LEVEL: Completed well.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 340 ft.	
Rotary Driven Domestic Industrial Municipal Domestic Municipal	Static level 142 ft. below land	surface. Date ///7/7
Dug ☐ Bored ☐ Irrigation Test Well Other ☐	Artesian pressure lbs. per squa	re inch. Date
CASING INSTALLED: Threaded Welded Welded Some Tit. to 17 2 ft. Gage 350	(12) WELL LOG: Diameter of well Depth drilled 472 ft. Depth of comp	eleted well 472 ft.
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and show thickness and nature of each stratu with at least one entry for each change of forms	ım and aquifer penetrated, ation. Report each change in
PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate prin	rcipal water-bearing strata. From To SWL
	BROWN SHALE	0 16
	GREEN SHALE	16 93
perforations from	HARD BLOWN SANDSTONE	93 123
perforations from	BROWN LAVA	123 158
perforations from ft. to ft.	BLACK LAVA	158 169
(7) SCREENS: Well screen installed? Yes No	BROWN LAVA	169 245
Manufacturer's Name	BLOKEN BROWN LAVA	242 378
Type Model No	BROKEN BLEY BASALT	328 33/
Diam Slot size Set from ft. to ft.	GLEY BASALT	331 340
Diam Slot size Set from ft. to ft.	BROWN LAVA DECOMPOSED	340 382 WB
(2) WELL TESTS. Drawdown is amount water level is	BLACK BASALT	382 412
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	BADWN LAUA	412 430
Was a pump test made? ✓ Yes □ No If yes, by whom? Amo Co	BAOWN BASALT	430 443
"eld: 1100 gal./min. with 7 ft. drawdown after 2 hrs.	BLOWN LAVA	443 45B V
" " "	BROWN BASHLT	458 472
" " "		
Bailer test gal./min. with ft. drawdown after hrs.		
Artesian flow g.p.m.		
nperature of water56 Depth artesian flow encountered ft.	Work started 11/19 1977 Complete	ted 6/33 19/8
(9) CONSTRUCTION:	Date well drilling machine moved off of well	6/23 1978
Well seal-Material used BENTONDIFE	Drilling Machine Operator's Certification This well was constructed under my	
Well sealed from land surface toft. Diameter of well bore to bottom of sealin.	Materials used and information reported	above are true to my
	best knowledge and belief.	20/0 70
Diameter of well bore below seal	[Signed] (Drilling Machine Operator)	Date, 19./5
Number of sacks of cement used in well seal sacks	Drilling Machine Operator's License No656	
Number of sacks of bentonite used in well sealsacks	Drining Muchine Operator 5 Entertain	
Brand name of bentonite AQUA-GEL	Water Well Contractor's Certification:	
Number of pounds of bentonite per 100 gallons of water	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
Was a drive shoe used? Yes No Plugs Size: location ft.	Name GE. STOREY & SON WELL DAILING INC	
Did any strata contain unusable water? Yes	(Person, firm or corporation)	(Type or print)
Type of water? depth of strata	Address 3647 Hole ST	ELAMATH MILLS
Method of sealing strata off	[Signed]	
Was well gravel packed? ☐ Yes No Size of gravel:	(Water Well Cont	ractor)
Gravel placed from ft. to ft.	Contractor's License No Date	19/9 , 1978
· · · · · · · · · · · · · · · · · · ·		