

WATER WELL REPORT
STATE OF OREGON

KLAM
2387

RECEIVED

FEB 14 1985

PLEASE TYPE OR PRINT IN INK
WATER RESOURCES DEPT

SALEM, OREGON

State Well No. 37S/12E-500

State Permit No.

(1) OWNER:

Name Wallace Plemons
Address P.O. Box 154
City Beatty State Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Test Well Other
 Bored Thermal: Withdrawal Reinjection

(4) PROPOSED USE (check):

CASING INSTALLED: Steel Plastic
Threaded Welded
12" Diam. from 1 ft. to 71 ft. Gauge .250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
d. gal./min. with ft. drawdown after hrs.
Air test 1000 gal./min. with drill stem at 61 ft. 2 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 49 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used Cement
Well sealed from land surface to 71 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 30 sacks
How was cement grout placed? Pumped

Was pump installed? No Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number
NE 1/4 NE 1/4 Section 5 T. 37S R. 12E W.M.
Tax Lot # Lot Blk Subdivision
Address at well location:

(11) WATER LEVEL: Completed well.

Depth at which water was first found 54 ft.
Static level 22" ft. below land surface. Date 1-7-84
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 340 ft. Depth of completed well 340 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Brown Clay Soil	0	2	
Broken Blue & Brown Rock	2	12	
Hard Yellow Clay	12	16	
Blue Sandstone	16	18	
Hard Yellow Clay	18	22	
Blue Sandstone	22	30	
Blue Rock	30	46	
White Pumie Rock	46	54	
Hard Blue Rock	54	59	
White Pumie Rock	59	65	
Hard Blue Rock	65	106	
Brown Lava	106	130	
Grey Basalt	130	175	
Red Rock	175	195	
Brown Rock	195	294	
Red Rock	294	328	
Hard Grey Basalt	328	340	22"

Work started 12-8 19 84 Completed 1-7 19 85
Date well drilling machine moved off of well 1-7 19 85

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date, 19

Bonded Water Well Constructor Certification:
Bond 28040810 Issued by: Western Surety Co.
(number) Surety Company Name

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Roger Chancellor Well-Drilling
(Person, firm or corporation) (Type or print)
Address 5223 Valley View Lane, K. Falls.
[Signed] Roger Chancellor Water Well Constructor
Date 2-7, 19 85