

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

KLAMATH
498

NC

RECEIVED
FEB 6 1969

27/B-21

RECEIVED
JAN 13 1969
STATE ENGINEER
SALEM OREGON

STATE ENGINEER WATER WELL REPORT

STATE OF OREGON
(Please type or print)

STATE ENGINEER
SALEM, OREGON

State Well No. ~~716-27~~

Permit No. ~~716-27~~

(1) OWNER:

Name Edgar Coburn
Address Chemult Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dip Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 62 ft. Gage 250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used Cutting Torch
Size of perforations 1/4 in. by 6 in.
48 perforations from 37 ft. to 62 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

level 28 ft. below land surface Date 12-9-68
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Self
15 gal./min. with 0 ft. drawdown after 4 hrs.

Baller test

6 gal./min. with 0 ft. drawdown after 1 hrs.

Artesian flow

g.p.m. Date _____
Temperature of water 53 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Bentonites Cement
Depth of seal _____ 35 ft.
Diameter of well bore to bottom of seal _____ 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: 3/4
Gravel placed from 65 ft. to 35 ft.

(11) LOCATION OF WELL:

County: Harney Driller's well number _____
27 Section 27 T. 21S R. 8 E W.M.
Bearing and distance from section or subdivision corner
Chalet Cape

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 65 ft. Depth of completed well 65 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
<u>Brown Hard pan</u>	<u>0</u>	<u>37</u>	
<u>White Pumice</u>	<u>37</u>	<u>58</u>	
<u>White Pumice & Gravel</u>	<u>58</u>	<u>65</u>	

Work started 12-1- 1968 Completed 12-9- 1968
Date well drilling machine moved off of well 12-11- 1968

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Kenneth Mathers Date 1-10- 1969
(Drilling Machine Operator)

Drilling Machine Operator's License No. 245

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME MATHERS + SON
(Person, firm or corporation) (Type or print)

Address RT. 2 BOX 180 BEND, Ore.

[Signed] Kenneth Mathers
(Water Well Contractor)

Contractor's License No. 262 Date 1-10- 1968