

RECEIVED

KLAM 50328

KLAM 50328

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

JAN 7 1963 WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 39/10 - 96

G-4899

State Permit No.

(1) OWNER:

Name Arthur W. Reed
Address Rt. 2 Box 810 D.A.
Klamath Falls, Oregon

(2) LOCATION OF WELL:

County Klamath Driller's well number
S.W. 1/4 N.E. 1/4 Section 9 T.39 S. R. 10 E. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 50 ft. Threaded Welded Gage 4"

(7) PERFORATIONS:

Perforated? Yes No

Table with 4 columns: Size of perforations, in., by, in., ft. to, ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal drove to seat in clay
Depth of seal 50 ft. Was a packer used? No
Diameter of well bore to bottom of seal 12 in.
Were any loose strata cemented off? Yes No
Was a drive shoe used? Yes No
Was well gravel packed? Yes No
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 153 ft. below land surface Date 12/24/62
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Interstate
Was a pump test made? Yes No If yes, by whom? Pump Co.
Yield: 330 gal./min. with 67 ft. drawdown after 4 hrs.
Ballor test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 60 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 10"
Depth drilled 971 ft. Depth of completed well 971 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO

Work started 11/19 19 62 Completed 12/24 19 62
Date well drilling machine moved off of well 12/24 19 62

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John A. Van Meter
(Person, firm or corporation) (Type or print)
Address Box 204 Malin, Oregon

Drilling Machine Operator's License No. 183

[Signed] John A. Van Meter
(Water Well Contractor)

Contractor's License No. 170 Date 1/2 19 63