KLAM 57397

STATE OF OREGON WATER SUPPLY WELL REPORT

(ORS 537.765 & OAR 690-205-0210)

Instructions for completing this report are on the last page of this form.

WELL LABEL # L 103028 START CARD# 202967
ORIGINAL LOG# KL. 14838

(1) LANDOWNER Owner Well I.D.	(9) LOÇATION OF WELL (legal description)
First Name Last Name TRUST	County KLAMATH Two 40 Norsh Range 12 (E)r W W.M.
Address 38403 FILET RD.	Sec 33 NE 1/4 of the NW 1/4 Tax Lot 400
City MALIN State OR Zip 97632	Tax Map Number Lot Lat ° ' . "or . DMS or DD
(2) TYPE OF WORK New Conversion Deepening	Long ° ' or DMS or DD
Alteration (complete Sections 2a & 10) Abandonment (complete Section 5a)	Street Address of Well (or nearest address) 30403 PLEASTER
(2a) PRE-ALTERATION: Well Depth 238 / ft. Seal Material CEMENT	MALIN, OTE
Casing Type: Steel Plastic Other Casing Gauge 3/16" Casing Diameter 16"	(10) STATIC WATER LEVEL Date SWL(psi) + SWL (ft)
casing dauge	Existing Well/Pre-Alteration 4-67-10 - 174
(3) DRILL METHOD Rotary Air Rotary Mud Auger	Completed Well 4-29-10 - 174
☐ Cable ☐ Cable Mud ☐ Reverse Rotary ☐ Other	Flowing Artesian? Yes Dry Hole? Yes
(4) PROPOSED USE Domestic Trigation Community	WATER BEARING ZONES Depth water was first found
☐ Industrial/Commercial ☐ Livestock ☐ Dewatering ☐ Injection	SWL Date From To Est Flow SWL (psi) + SWL (ft)
Thermal Other	4-29-10 238 420 400+ - 174
(5) BORE HOLE CONSTRUCTION Depth of Completed Well 420 ft. Special Standard: Yes (attach copy)	
BORE HOLE SEAL Dia From To Material From To Amount Scks/lbs	
16 0 238 SEE ORIG LOC # KL 14838	(11) WELL LOG Ground Elevation
12" 238 285	Material From To
12" 285 420	FROM 0-238 SEE ORIGINAL
How was seal placed: Method	WELL LOG KLAM 14838
Other	BROKEN - FRACTURED 242
Backfill placed from ft. to ft. Material	BASALT WITH CINDERS 420
'ilter pack from ft. to ft. Material Size	DEACHED
(5a) ABANDONMENT USING UNHYDRATED BENTONITE:	HEVEIVED
Calculated Amount Proposed to be Used:sacks/lbs	MAY 1 4 2010
Actual Amount Used:sacks/lbs	mm 8 4 6000
(6) CASING/LINER	WATER RESOURCES DEPT
Csng Linr Dia + From To Gauge Steel Plastic Welded Thrd	SALEM, OREGON
SEE ORIG. LOG " KL 14838	
	Date Started 4-20-10 Completed 4-29-10
Shoe Inside Outside Other Location of shoe(s)	(unbonded) Water Well Constructor Certification I certify that the work I performed on the construction, deepening, alteration, or
Temporary casing Yes Diameter From To	abandonment of this well is in compliance with Oregon water supply well
(7) PERFORATIONS/SCREENS	construction standards. Materials used and information reported above are true to the best of my knowledge and belief.
Perforations Method	1739
Screens Type Material	License Number 1739 Date 5-07-10 Signed Church Company
Screen Screen Tele/ Slot Slot # of pipe	Signed character of
Perf Scrn Csng Linr Dia From To width length slots size	(bonded) Water Well Constructor Certification
	I accept responsibility for the construction, deepening, alteration, or
	abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water
	supply well construction standards. This report is true to the best of my knowledge
(8) WELL TESTS: Minimum testing time is 1 hour	and belief.
✓ Pump ☐ Bailer ☐ Air ☐ Flowing Artesian	License Number 1355 Date 5.07.10
Yield gal/min Drawdown Drill stem Pump depth Duration (hr)	Signed Lithur Litry
1400 20' 200' 4h	Signed Contact Info. (optional)
emperature 38 °F Lab analysis Yes By	(chicago)
Water quality concerns? Yes (describe below) TDSppm From ToDescription Amount Units	JUL 2 8 2010
	WATER HESOURCES DEPT