KLAM 57529

STATE OF OREGON WATER SUPPLY WELL REPORT (as required by ORS 537.765 & OAR 690-205-0210)

09-16-2010

Page 1 of 1

WELL LABEL # L	100398
START CARD#	1010639

(1) LAND OWNER Owner Well 1.D.#2	(9) LOCATION OF WELL (legal description)		
First Name Last Name	County Klamath Twp 41.00 S N/S Range 11.00 E E	/W WM	
Company KLAMATH COUNTY SCHOOL DISTRICT	Sec 10 SW 1/4 of the SE 1/4 Tax Lot 100		
Address 10501 WASHBURN WAY	Tax Map Number Lot		
City KLAMATH FALLS State OR Zip 97603		or DD	
(2) TYPE OF WORK New Well Deepening Conversion	Long O O DMS	or DD	
Alteration (repair/recondition) Abandonment	Street address of well Nearest address		
(3) DRILL METHOD	23330 HIGHWAY 50, MERRILL, OREGON 97633		
Rotary Air Rotary Mud Cable Auger Cable Mud Reverse Rotary Other	(10) STATIC WATER LEVEL Date SWL(psi) + SWL	(ft)	
(4) PROPOSED USE Domestic Irrigation Community	Existing Well / Predeepening		
Industrial/ Commercial Livestock Dewatering	Completed Well 07-21-2010 66		
Thermal Injection Other MUNICIPAL	Flowing Artesian? Dry Hole?		
	WATER BEARING ZONES Depth water was first found 92		
(5) BORE HOLE CONSTRUCTION Special Standard (Attach copy)			
Depth of Completed Well 303.00 ft. BORE HOLE SEAL sacks/	07-14-2010 92 131 200 99 07-16-2010 172 192 500 99		
BORE HOLE SEAL sacks/ Dia From To Material From To Amt lbs	07-19-2010 172 192 300 97-19-2010 211 303 500		
14.75 0 202 Bentonite Chips 0 6 7 S	0.517-2010 211 503 500		
9.87 202 303 Cement 6 202 115 S			
	(11) WELL LOG Ground Flevation		
	Ground Dievation	-	
How was seal placed: Method A B C D E	Material From To		
Other	Soft Sandy Loam 0 21 Redish Claystone 21 25		
Backfill placed from ft. to ft. Material	To a Vallan Clauster		
Filter pack from ft. to ft. Material Size	Broken Rubble Ash & Cinders 25 84 104		
xplosives used: Yes Type Amount	Claystone & Shale Layers Mixed Green & Tan 104 172		
(6) CASING/LINER	Weathered Brown Rock 172 176		
(6) CASING/LINER Casing Liner Dia + From To Gauge Stl Plstc Wld Thrd	Black Basalt 176 179		
	Softer Brown Rock Decomposed 179 192		
● C 10 ≥ 2.5 202 .250 ● C ≥ 193 303 .188 ● C ≥ 193 303 .188	Hard Black Basalt 192 211		
	Softer Black Basalt with Brown Ash & Cinders 211 228 Basalt with Rubble & Shale Strips 228 247		
	Constant Constant		
	Gray & Green Sitistone 247 286 Hard Broken Basalt 286 291		
Shoe Inside Outside Other Location of shoe(s)	Broken Gray & Brown Basalt 291 303		
Temp casing Yes Dia From To			
(7) PERFORATIONS/SCREENS			
Perforations Method Factory Saw			
Screens Type Material		-	
Perf/S Casing/ Screen Scrn/slot Slot # of Tele/	D. C I		
creen Liner Dia From To width length slots pipe size	Date Started 07-13-2010 Completed 07-23-2010		
Perf Liner 8 240 303 125 3 1,008	(unbonded) Water Well Constructor Certification		
	I certify that the work I performed on the construction, deepening, alteral	tion, or	
	abandonment of this well is in compliance with Oregon water suppl construction standards. Materials used and information reported above are		
	the best of my knowledge and belief.	iruc to	
(O) WELL PECTS, M	, -		
(8) WELL TESTS: Minimum testing time is 1 hour	License Number Date Electronically Filed		
Pump Bailer Air Flowing Artesian	Signed		
Yield gal/min Drawdown Drill stem/Pump depth Duration (hr)			
245 5 150 24	(bonded) Water Well Constructor Certification		
	I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above. All work		
Temperature 64 °F Lab analysis Yes By	performed during this time is in compliance with Oregon water supp		
Water quality concerns? Yes (describe below)	construction standards. This report is true to the best of my knowledge and		
From To Description Amount Units	License Number 1385 Date 09-16-2010		
	Electronically Filed		
	Signed ROBERT BUCKNER (E-filed)		
	Contact Info (optional)		
4			

