

# NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED  
JUN 21 1966

## WATER WELL REPORT

STATE OF OREGON  
(Please type or print)

Klam  
670

State Well No. 31/8-6 C

State Permit No.

### (1) OWNER:

Name BEN ADAIR  
Address RT 2 Box 685B  
KLAMATH FALLS, ORE.

### (2) LOCATION OF WELL:

County KLAMATH Driller's well number  
NE 1/4 NW 1/4 Section 6 T. 31S R. 8E W.M.  
Bearing and distance from section or subdivision corner

### (3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐  
Abandonment, describe material and procedure in Item 12.

### (4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐  
Irrigation ☒ Test Well ☐ Other ☐

### (5) TYPE OF WELL:

Rotary ☐ Driven ☐  
Cable ☒ Jetted ☐  
Dug ☐ Bored ☐

### (6) CASING INSTALLED:

Threaded ☐ Welded ☒  
20" Diam. from 16" to 27 1/2" ft. Gage 250  
16" Diam. from 11.2" ft. Gage 250

### (7) PERFORATIONS:

Perforated? ☒ Yes ☐ No  
Type of perforator used FACTORY SLOT  
Size of perforations 1/4 in. by 2 in.  
1470 perforations from 42'6" to 112 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

### (8) SCREENS:

Well screen installed? ☐ Yes ☒ No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

### (9) CONSTRUCTION:

Well seal—Material used in seal CONCRETE & BENTONITE  
Depth of seal 20 ft. Was a packer used? NO  
Diameter of well bore to bottom of seal 24 in.  
Were any loose strata cemented off? ☐ Yes ☒ No Depth  
Was a drive shoe used? ☒ Yes ☐ No  
Was well gravel packed? ☒ Yes ☐ No Size of gravel: 1/4-3/4  
Gravel placed from 0 ft. to 65 ft.  
Did any strata contain unusable water? ☐ Yes ☒ No  
Type of water? Depth of strata  
Method of sealing strata off

### (10) WATER LEVELS:

Static level 5 ft. below land surface Date 5/27/64  
Artesian pressure lbs. per square inch Date

### (11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made? ☒ Yes ☐ No If yes, by whom? VALLEY PUMP  
Yield: gal./min. with ft. drawdown after hrs.  
" 3500 " 55 " 3 "  
" " " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 43 Was a chemical analysis made? ☐ Yes ☒ No

### (12) WELL LOG:

Diameter of well below casing 16  
Depth drilled 274 ft. Depth of completed well 274 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	1
YELLOW CLAY & PUMICE	1	10
YELLOW CLAY	10	20
PUMICE	20	65
BLACK CINDERS	65	111
YELLOW CHALK	111	112
BROWN LAVA	112	122
GRAY BASALT BOULDERS	122	132
BROWN LAVA	132	146
GRAY BASALT	146	181
GREEN SHALE	181	189
GRAY BASALT	189	206
BROWN LAVA	206	220
BROKEN BLACK LAVA	220	274

Work started 4/26/66 19 Completed 5/24/66 19  
Date well drilling machine moved off of well 5/27/66 19

### (13) PUMP:

Manufacturer's Name  
Type: H.P.

### Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME EE STOREY  
(Person, firm or corporation) (Type or print)

Address 3831 Hope Klamath Falls, Ore.

Drilling Machine Operator's License No. 115

[Signed] EE Storey  
(Water Well Contractor)

Contractor's License No. 74 Date 5/30/66 19

(USE ADDITIONAL SHEETS IF NECESSARY)