

RECEIVED  
OCT 11 1962

WATER WELL REPORT

Klam  
672

State Well No. 31/8-10D

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER STATE OF OREGON

G2670

State Permit No.

(1) OWNER:

Name Warner Valley Stock Co.

Address Klamath Falls, Oregon

(2) LOCATION OF WELL:

County Klamath

Owner's number, if any—

N.W. 1/4 N.W. 1/4 Section 10 T. 31 S. R. 8 E. W.M.

Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded

18" Diam. from 0 ft. to 156 ft. Gage 1/4  
20" Diam. from 0 ft. to 28 ft. Gage 1/4  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated?  Yes  No

Type of perforator used factory

SIZE of perforations 3/16 in. by 1 1/2 in.  
perforations from 26 ft. to 150 ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS:

Well screen installed  Yes  No

Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Was a surface seal provided?  Yes  No To what depth? 26 ft.  
Material used in seal— Portland cement  
Did any strata contain unusable water?  Yes  No  
Type of water? Depth of strata  
Method of sealing strata off

(10) WATER LEVELS:

Static level 0 ft. below land surface Date 10/4/62  
Artesian pressure 2 lbs. per square inch Date 10/4/62

Log Accepted by: Warner Valley Stock Co.

[Signed] [Signature] Date 10-8, 1962  
[Signature] (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level. Interstate Pump Co.

Was a pump test made?  Yes  No If yes, by whom? Interstate Pump Co.  
Yield: 1500 gal./min. with 7 ft. drawdown after 3 hrs.

Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow 75 g.p.m. Date 10/4/62  
Temperature of water 42 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well 18 inches.

Depth drilled 160 ft. Depth of completed well 104 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
peat and top soil	0	4 1/2
white pumice	4 1/2	7
pink pumice and sand	7	29
white pumice and sand	29	42
black sand and pumice	42	52
course quick sand, some gravel	52	58
packed sand and pumice	58	73
loose course sand and pumice	73	82
sandstone	82	85
quick sand and gravel	85	87
packed sand and pumice	87	89
clay and pumice	89	91
big gravel and sand	91	97
yellow clay	97	100
sandstone	100	103
sand, gravel & pumice	103	139
cemented gravel	139	142
gravel and sand	142	156
gray lava	156	160

Work started 9/19 1962, Completed 10/4 1962

(13) PUMP:

Manufacturer's Name  
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John A. Van Meter  
(Person, firm, or corporation) (Type or print)

Address Box 204 Malin, Oregon

Driller's well number

[Signed] [Signature] (Well Driller)

License No. 170 Date 10/8, 1962