

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER WELL REPORT

L.P.S. checked

*Klam
675*

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

STATE OF OREGON
(Please type or print)

State Well No. 315/RE-20cb

State Permit No. _____

(Do not write above this line)

(1) OWNER:

Name John M. Mosby
Address P.O. Box 1175 Lompoc, Calif. 93436

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Driven
Jetted
Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
20" Diam. from 0 ft. to 25 1/2 ft. Gage 1/4"
18" Diam. from 0 ft. to 322 ft. Gage 1/4"
" Diam. from _____ ft. to _____ ft. Gage _____"

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used Factory
Size of perforations 1/8 in. by 3 in.
perforations from 56 ft. to 322 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Is a pump test made? Yes No If yes, by whom? owner
Yield: 4000 gal./min. with 76 ft. drawdown after 4 hrs.

Artesian flow _____ g.p.m.
Temperature of water 48 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used cement
Well sealed from land surface to 25 ft.
Diameter of well bore to bottom of seal 24 in.
Diameter of well bore below seal 18 in.
Number of sacks of cement used in well seal 59 sacks
How was cement grout placed? grout pipe

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number _____
N.W. 1/4 S.W. 1/4 Section 20 T. 31 S. R. 8 E. W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 4 ft.
Static level 4 ft. below land surface. Date 7/31/78
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 18
Depth drilled 322 ft. Depth of completed well 322 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top soil	0	1	
pumice	1	26	4
sand, gravel & pumice	26	40	"
brown sand	40	46	"
brown sandstone	46	52	"
XXXX coarse sand, pea gravel & pumice	52	154	"
coarse sand & pumice	154	156	"
pea gravel & clay	156	160	"
brown gravel & sand	160	196	"
brown clay & gravel	196	202	"
1/2" minus gravel & sand	202	322	"

RECEIVED

SEP 10 1979

WATER RESOURCES DEPT
SALEM, OREGON

Work started 6/17/78 19 Completed 7/31 19 78
Date well drilling machine moved off of well 7/31 19 78

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] John A. Van Meter Date 9/5, 1979
(Drilling Machine Operator) 118

Drilling Machine Operator's License No. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name John A. Van Meter
(Person, firm or corporation) (Type or print)

Address P.O. Box 204 Malin, Oregon

[Signed] John A. Van Meter
(Water Well Contractor)

Contractor's License No. 170 Date 9/5, 1979