NOTICE TO WATER WELL CONTRACTOR The original and first copy

of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT CEIVED

STATE OF OREGON OCT &

1974 State Well No. 345 7E-31 Cd

(Please type or print) STATE ENGINEERState Permit No. ...

(Do not write above this lingALEM, OREGOII

6-6720

(1) OWNER:	(10) LOCATION OF WELL:	
Name James Heltzel	County Klamath Driller's well number	
Address P. O. Box 61	SE ¼ SW ¼ Section 31 T. 34 S R. 34=\$ 7 E W.B	<u>—</u> М.
Chiloquin Oregon 97624	Bearing and distance from section or subdivision corner	
(2) TYPE OF WORK (check):	-	
New Well 🔀 Deepening □ Reconditioning □ Abandon □		_
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):		£ŧ.
Rotary Driven Domestic Dindustrial Diffusional D		<u>ft.</u>
Cable	7, 12,	
and a second and a second a se	Artesian pressure 2 lbs. per square inch. Date 9,246,	_74 _
CASING INSTALLED: Threaded [] Welded [2]	(12) WELL LOG: Diameter of well below casing	
8		ft.
	Formation: Describe color, texture, grain size and structure of material	
" Diam. from ft. to ft. Gage	and show thickness and nature of each stratum and aquifer penetrated	d,
PERFORATIONS: Perforated?   Yes   T-No.	with at least one entry for each change of formation. Report each change is position of Static Water Level and indicate principal water-bearing strat	
PERFURATIONS: Perforated? ☐ Yes ☐ No.  Type of perforator used		
	MATERIAL From To SWL	_
Size of perforations in. by in.	Sandy top soil 0 8	_
perforations fromft. toft.	Clay and gravel 8 20	
perforations from ft. to ft	Blue clay   20   67	_
periorations from	Coarse gravel 67 70 0'	-
(7) SCREENS: Well screen installed?   Yes No		
Manufacturer's Name		
Type Model No		
Diam Slot size Set from ft. to ft.		_
Diam. Slot size Set from ft. to ft.		
(8) WELL TESTS: Drawdown is amount water level is		
lowered below static level		_
Was a pump test made? ☐ Yes ☐ No If yes, by whom?		_
Yield: gal./min. with ft. drawdown after hrs.		_
" "		
" "		_
Bailer test 100 gal./min. with 7 ft. drawdown after 1 hrs.		
Artesian flow 35 g.p.m.		_
perature of water 55 Depth artesian flow encounteredft.	Work started 9, 18, 1974 Completed 9, 19, 197	— ;
(0) CONSTRUCTION.	Date well drilling machine moved off of well 9, 27, 19 7	
(9) CONSTRUCTION:		
Well seal—Material usedCement	Drilling Machine Operator's Certification:  This well was constructed under my direct supervision	_
Well sealed from land surface toft.	Materials used and information reported above are true to m	.ı. 1 <b>y</b>
Diameter of well bore to bottom of seal .10 in.	best knowledge and belief.	
Diameter of well bore below seal8 in.  Number of sacks of cement used in well seal 8 sacks	[Signed] (Drilling Machine Operator) Date 9, 30, 19.7	.4
Number of sacks of cement used in well seal 0	Drilling Machine Operator's License No. 196	
Brand name of bentonite		_
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:	
of water lbs./100 gals.	This well was drilled under my jurisdiction and this report i	is
Was a drive shoe used? ☑ Yes ☐ No Plugs Size: location ft.	true to the best of my knowledge and belief.	
Did any strata contain unusable water? 🗌 Yes 🕱 No	Name Norm Sevey Well Drilling (Type or print)	
Type of water? depth of strata	Address 5619 Leland Dr. Klamath Falls, Oregon	
Method of sealing strata off		
Was well gravel packed? [] Yes [ No Size of gravel:	[Signed] (Water Well Contractor)	
Gravel placed fromft. toft.	Contractor's License No. 408 Date 9, 30, 1974	,
The process of the control of the co	Date, 1974	4.