WATER WELL REPORT STATE OF OREGON

RECEIVED

JUL 20 1981

State Well No.

WATER RESOURCES DEPTate Permit N SALEM, OREGON

c	28/15	-20	ba
•			
ĺο.	5-9	463	

(1) OWNER:	(10) LOCATION OF WELL:		
Name LAWRENCE LVERSON	County LAKE Driller's well number 622		
Address STAR ROUTE	NE 4 NW 4 Section 20 T. 28 R. 15 E W.M.		
City SILVER LAKE State CR 9639	Tax Lot # Lot Blk Subdivision		
(2) TYPE OF WORK (check):	Address at well location:		
New Well	(11) WATER LEVEL: Completed well.		
If abandonment, describe material and procedure in Item 12.	- LE		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found ft. Static level 24 2 ft. below land surface. Date 6-72-8		
Rotary Air Driven	Artesian pressure lbs. per square inch. Date		
Rotary Mud	(12) WELL LOG: Diameter of well below casing 12 1/2.		
CEN CLACIFIC PATCHALL PR	Depth drilled 65 ft. Depth of completed well 65 ft.		
(5) CASING INSTALLED: Steel Plastic Welded Welded Plastic Welded P	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.		
LINER INSTALLED:	MATERIAL From To SWL		
	BLOWN SOIL 0 2		
A	BLOWN SANDY CLAY 2 16		
(6) PERFORATIONS: Perforated? ☐ Yes W No Type of perforator used	YELLOWCLAY 16 20		
Size of perforations in. by in.	GREEN SANDY CLAY 20 27		
	GREEN CLAY 27 64		
perforations from ft. to ft.	COMENTON GRAVEL 64 72		
perforations from	BROWN-INECINDERS 72 160		
/	BROKEN KOCK 160 105		
(7) SCREENS: Well screen installed? Yes W No			
Manufacturer's Name			
Type Model No. Diam. Slot Size Set from ft. to ft.			
Diam. Slot Size Set from ft. to ft.			
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? Yes No. If yes, by whom?			
d: gal./min. with ft. drawdown after hrs.			
" " " "			
Air test 900 gal./min. with drill stem at 150t. hrs.			
Bailer test gal/min. with ft. drawdown after hrs.			
A esian flow g.p.m.			
perature of water 58° Depth artesian flow encountered	Work started 6-2.2 198 Completed 6-23 198		
(9) CONSTRUCTION: Special standards: Yes □ No 💆	Date well drilling machine moved off of well 6-23 1981		
Well seal—Material used CEMENT	Drilling Machine Operator's Certification:		
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used		
Diameter of well bore to bottom of sealin.	and information reported above are true to my best knowledge and belief.		
Diameter of well bore below seal	[Signed] Date 14, 135		
Number of sacks of cement used in well seal How was cement grout placed? Sacks	Drilling Machine Operator's License No.		
How was cement grout placed?	Water Well Contractor's Certification:		
	This well was drilled under my jurisdiction and this report is true to		
Was pump installed? Type — HP Depth ft.	the best of my knowledge and bolief		
Was a drive shoe used? ☐ Yes WNo Plugs NO Size location	Name Power State Control of the Cont		
Did any strata contain unusable water? Yes No Not Awa(YZEI)	(Person, firm 199500 Sentiam Hwy. (Type or print) Address		
Type of Water? depth of strata	TEDONON, OK 47535		
Method of sealing strata off	[Signed] (Water Well Contractor)		
Was well gravel packed? ☐ Yes W No Size of gravel:	Contractor's License No. 514 Date 7-14 181		
Gravel placed from ft. to ft.			