

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED

OCT 14 WATER WELL REPORT

STATE ENGINEER STATE OF OREGON
 SALEM, OREGON

Lake 1372

State Well No. 28/16-2R
 State Permit No. Q-5875

(1) OWNER:

Name DELBERT BLACK
 Address 1338 GILMORE DR.
 SAN LEANDRO, CALIFORNIA

(2) LOCATION OF WELL:

County LAITE Driller's well number BLACK #1
 SE 1/4 SE 1/4 Section 2 T. 28S R. 16E W.M.
 Bearing and distance from section or subdivision corner
 APPROX. 200' NORTH AND 75' WEST FROM THE SE CORNER OF SECTION 2 T 28 S R 16 E W.M.

(3) TYPE OF WORK (check):

Drill Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
 1 1/4" Diam. from 0 ft. to 20 ft. Gage 1/4
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used
 Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name
 Model No.
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CONCRETE
 Depth of seal 20 ft. Was a packer used? NO
 Diameter of well bore to bottom of seal 20 in.
 Were any loose strata cemented off? Yes No Depth
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel:
 Gravel placed from ft. to ft.
 Did any strata contain unusable water? Yes No
 Type of water? Depth of strata
 Method of sealing strata off

(10) WATER LEVELS:

Static level 24 ft. below land surface Date 9-20-63
 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? J. PETTUS
 Yield: 500 gal./min. with 56 ft. drawdown after 6 hrs.
 " " " "
 " " " "
 Bailer test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m. Date
 Temperature of water 56° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 12" + 8"
 Depth drilled 320 ft. Depth of completed well 320 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
SANDY LOAM, TOP SOIL	0	5
CLAY, BROWN	5	20
CLAY, BLUE	20	30
GRAVEL, SMALL, WHITE, WATER LEVEL 22'	30	45
GRAVEL, SMALL, WHITE, ROCK & CINDERS	45	75
LAVA ROCK, BLACK, HARD, WATER LEVEL RAISED TO 16' AT 75' DEPTH.	75	98
SANDSTONE, BLACK, HARD	98	100
LAVA ROCK, BLACK, HARD, PORES	100	120
WATER LEVEL DROPPED TO 22'		
LAVA ROCK, BLACK, HARD	120	125
LAVA ROCK, BLACK, PORES	125	165
LAVA ROCK, BLACK, HARD	165	202
WATER LEVEL DROPPED TO 23'		
LAVA ROCK, BLACK, PORES	202	225
CHANGED TO 8" BIT AT 202'		
LAVA ROCK, BLACK, HARD	225	262
LAVA ROCK, RED-BLACK, BURNED	262	301
WITH SOME CINDERS, SOFT WATER LEVEL DROPPED TO 24'		
SANDSTONE, GREY, HARD	301	315
SAND, BLACK, FINE	315	320

Work started 8-15 1963 Completed 9-19 1963
 Date well drilling machine moved off of well 9-19 1963

(13) PUMP:

Manufacturer's Name
 Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME JOHN A. PETTUS
 (Person, firm or corporation) (Type or print)

Address CHRISTMAS VALLEY SILVER LAKE, ORE

Drilling Machine Operator's License No. 287

[Signed] John A. Pettus
 (Water Well Contractor)

Contractor's License No. 401 Date Sept 26 1963