1639 **REPORT** AUUZ & 13/4 STATE OF OREGON STATE ENGINEER Well No.
(Please type or print) SALEM, OREGON Permit No.

(Do not write at	Nove can me,
(1) OWNER: W-	(10) LOCATION OF WELL:
Name CITY OF PAISLEY	County Lake Driller's well number
Address Paisley, Oregon	SE 14 30 14 Section 24 T. 33 S R. 18 E. W.M.
	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	Within 60 flot strip of alley-way in
New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐	Paislaw, Oregon
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 67
Rotary Driven Domestic Industrial Municipal	Static level 38 ft. below land surface. Date 8/15/74
Cable	Tt. below land surface. Date of 2.5/3 m
	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded Welded 250 tt to 200 tt Gage 250	(12) WELL LOG: Diameter of well below casing 0
	Depth drilled 205 ft. Depth of completed well 205
Diam. from	Formation: Describe color, texture, grain size and structure of materials:
ft. toft. Gage	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in
PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used Factory Perforations	MATERIAL From To SWL
Size of perforations 3/32 in. by 3 in.	Soil Zone (Gravel-Brown) 0 2
2400 perforations from 60 ft. to 180 ft.	Boulders & Gravel 2 15
perforations from ft. to ft.	Gravel h Clay (Brown) 15 67
perforations from ft. to ft.	Gravel (fine) Sand (coarse67 82 38
(7) COPERIG.	(Primary Water Aquifer)
(7) SCREENS: Well screen installed? ☐ Yes ☑ No	Clay, Gravel, Boolders 82 162
Manufacturer's Name	Cemented Gravel & Boulder 102 145
Type Model No Diam Slot size Set from ft. to ft.	Clay, Gravel, & Boulders 145 205
Diam. Slot size Set from ft. to ft.	
John Strade Stra	Water Supplies & Swim Peels Oregon State Board of Health
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? Yes No If yes, by whom? Oriller	
Vield: 130 gal./min. with 14 ft. drawdown after 24 hrs.	AUG 2 0 1974
" " " "	
" " "	
	DNF TEMP PERM
Bailer test gal./min. with ft. drawdown after hrs.	
tesian flow g.p.m.	2/05/2/
erature of water Depth artesian flow encountered	Work started 7/26/1974 Completed 8/1.5/19 74
(9) CONSTRUCTION:	Date well drilling machine moved off of well 0/15/19 74
Well seal-Material used Cement & Bentonite	Drilling Machine Operator's Certification:
Well sealed from land surface with 40 of 18" Jonducto	This well was constructed under my direct supervision.
Diameter of well bore to bottom of seal in.	Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal in.	[Signed] Sow Stook Kerry Date 8/15/19 74
Number of sacks of cement used in well sealsacks	(Drilling Machine Operator)
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No.
Brand name of bentonite	Water Well Contractor's Certification:
Number of pounds of bentonite per 100 gallons	
of waterlbs./100 gals.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? Yes No Plugs Size: location ft.	Name Jack Stooksheerly
Did any strata contain unusable water? Yes No	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address
Method of sealing strata off	[Signed] Jack Stooksberry 7.
Was well gravel packed? Yes No Size of gravel:	(Water Well Contractor)
Gravel placed from ft. to ft.	Contractor's License No. Date 19
(USE ADDITIONAL SH	EETS IF NECESSARV