

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED
 JUN 30 1969
 STATE ENGINEER
 SALEM, OREGON

STATE OF OREGON WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date of well completion.

(Please type or print)
 not write above this line

Lake 1640
 G5003

State Well No. 33/18-24cd
 State Permit No. _____

(1) OWNER:

Name City of Paisley, Oregon
 Address Paisley, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
 6" Diam. from 0 ft. to 190 ft. Gage 250
 " Diam. from " ft. to " ft. Gage
 " Diam. from " ft. to " ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used saw cut
 Size of perforations 1/8 in. by 3 in.
 1200 perforations from 60 ft. to 190 ft.
 " perforations from " ft. to " ft.
 " perforations from " ft. to " ft.
 " perforations from " ft. to " ft.
 " perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 33 ft. below land surface Date 6/30/69
 Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? driller
 Yield: 125 gal./min. with 11 ft. drawdown after 24 hrs.
 " " " " " "
 " " " " " "
 Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water 56 Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used cement
 Depth of seal 21 ft.
 Diameter of well bore to bottom of seal 15 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: 3/8 to 5/4
 Gravel placed from 21 ft. to 190 ft.

(11) LOCATION OF WELL:

County Lake Driller's well number _____
 1/4 1/4 Section T. R. W.M.
 Bearing and distance from section or subdivision corner Lot 1 in W.Y. Miller addition/ starts at S.E. corner of lot 1 - 52' W, thence 34' N in city of Paisley alley way.

(12) WELL LOG:

Diameter of well below casing 97/8

Depth drilled 216 ft. Depth of completed well 190 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
soil zone, sandy	0	2	
boulders & hard clay, brn.	2	12	
gravel & clay, brn.	12	25	
volcanic gravel, red to black, fine	25	35	
gravel, brn. to white, fine	35	48	
clay & gravel, brown	48	60	
gravel, brn., med.	60	78	
cemented gravel	78	130	
gravel, loose, med.	130	136	
cemented gravel	136	193	
clay & gravel, blue	193	203	
cemented gravel	203	211	
basalt rock, brn. to blk.	211	216	

Work started 6/11/69 19 Completed 6/30/69 19
 Date well drilling machine moved off of well 6/30/69 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Jack Stoolsberry, Jr. Date 6/30, 1969
 (Drilling Machine Operator)

Drilling Machine Operator's License No. 45

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Jack Stoolsberry, Jr.
 (Person, firm or corporation) (Type or print)

Address Rte. 2, Box 47, Lakeview, Ore.

[Signed] Jack Stoolsberry, Jr.
 (Water Well Contractor)

Contractor's License No. 211 Date 6/30, 1969