The original and first copy of this report are to be filed with the NOTICE TO WATER WELL CONTRACTOR OF OF ORDER APR 2 1 1975 STATE OF OF		38s	19E-	-24d
STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion. SALEM OREGON 97310 CALE OREGON	or print STATE ENGINEED State Permit No			
(1) 0111220	(10) LOCATION OF WELL:			
	County Lake Driller's well number			
Address Lakeview, Oregon	½ SE ¼ Section 24 т. 38 п. 19E W.M.			
	Bearing and distance from section or subdivisio	n corner		 -
(2) TYPE OF WORK (check):	1	·		
New Well 🔀 Deepening 🗌 Reconditioning 🗎 Abandon 🗔	** T			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.			
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found ft.			
Rotary X Driven Domestic Industrial Municipal	Static level ft. below land surface. Date			
Cable	Artesian pressure Ibs. per square inch. Date			
Dug Bored I Irrigation A Test Well Uther U	Artesian pressure ibs. per square men.			
CASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well b	elow casi	ng2	21
12=3/4" Diam. from 0 ft. to 400 ft. Gage 250	Depth drilled 400 ft. Depth of comple		400	ft.
ft. Gage	Formation: Describe color, texture, grain size a		ure of n	naterials:
" Diam. fromft. toft. Gage	and show thickness and nature of each stratun	and aq	uifer per	netrated,
	with at least one entry for each change of format position of Static Water Level and indicate princ	ion. Repo ipal wate	rt each d er-bearin	nange in ig strata.
PERFORATIONS: Perforated? X Yes No.			то	SWL
of perforator used Factory (sawed)	MATERIAL	From		
Size of perforations in by 2 in.	Top soil	0	2	
perforations from	Sand stone streaks & Gravel	2	20	 ·
perforations from 80 ft. to 400 ft.	Grey clay		26	
perforations fromft. toft.	Coarse gravel		60	·
(7) SCREENS:	Grey clay	60	72	
(7) SCREENS: Well screen installed? ☐ Yes ☐XNo	Sand	72	77	· · · · ·
Manufacturer's Name	Grey clay	77 85	85 107	
Type Model No	Brown clay	107	109	
Diam. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.	Gravel (3/4) Brown Sandstone		113	
Diam. Slot size Set from	Gravel		3 148	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level terstate	Sandy brown clay		160	
Was a pump test made? Yes \(\subseteq \text{No If yes, by whom? Pump Co.} \)	Sandy brown clay	160	328	
	Brown clay & gravel	328	340	
Yield: 2000 gal./min. with /80 ft. drawdown after hrs.	Coarse Sand	340	349	
" " "	Grey-Blue clay gravel &			
" " "	sand	349	400	
Bailer test gal./min. with ft. drawdown after hrs.	* Y s. C.			
Artesian flow g.p.m.				
Temperature of water Depth artesian flow encountered ft.	Work started 6/17 19 74Complete	ed 7/	18	19 7
	Date well drilling machine moved off of well	7/18	3	19
CONSTRUCTION: Cement grout	Drilling Machine Operator's Certification:			
Well seal-Material used	This well was constructed under my	direct	super	vision.
Well sealed from land surface to 20 (24" Pipe) ft.	Materials used and information reported	above a	are true	e to my
Diameter of well bore to bottom of seal 32 in.	best knowledge and belief.		152	274
Diameter of well bore below seal	[Signed] Ken Keynoldo (Drilling Machine Operator)	Date	/	, 19//
Number of sacks of cement used in well seal	Drilling Machine Operator's License No.	947		
Number of sacks of bentonite used in well seal sacks				
Brand name of bentonite	Water Well Contractor's Certification:			
Number of pounds of bentonite per 100 gallons	This well was drilled under my jurisdiction and this report is			
of water lbs./100 gals. Was a drive shoe used? Yes Xoo Plugs Size: location ft.	true to the best of my knowledge and belief.			
Was a drive shoe used? Yes Ano Pluss Size: location	Name C & C Enloe Drilling Co	(Ts	pe or pri	int)
	Address	\		•
Type of water? depth of strata	10 1 1 E 1		***********	************
Method of sealing strata off	[Signed] Law V. Culoe			
Was well gravel packed? W Yes P No Size of gravel: 3/8 to 3/4	(Water Well Cont	-		~
Gravel placed from0 ft. to400 ft.	Contractor's License No503 Date	<u>د ره</u>		, 19?