The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT SALEM, OREGON 97310 (Please type	DEC 14 1981 State Well No. S	385/205-301
	ove the ATER RESOURCES DEPT No.	-
WATER RESOURCES DEPT.	The Pump! ORECON	
(1) OWNER: SALEM, OREGON (1)	(10) LOCATION OF WELL:	
Name Gren Diriginan	Lakety Lake Driller's well number	
	14 SE 14 Section 30 T. 38S R. 20E W.M.	
Lakeview, Oregon	Bearing and distance from section or subdivision	on corner
(2) TYPE OF WORK (check):		
New Well Deepening □ Reconditioning □ Abandon □ Reconditioning □ Item 19		
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	11/10/00
Rotary Driven Domestic Dindustrial Municipal Cable Jetted Domestic Dindustrial Municipal Domestic Dindustrial Dindustrial Domestic Dindustrial Dind	Static level 5 ft. below land s	urface. Date 11/18/79
Dug □ Bored □ Irrigation ☑ Test Well □ Other □	Artesian pressure lbs. per square	e inch. Date
(SCASING INSTALLED: Threaded Welded	(12) WELL LOG: Diameter of well b	
26 " Diam from 0 ft to 30 ft Gage • 375		
26 "Diam. from 0 ft. to 301 ft. Gage • 375 16 "Diam. from 0 ft. to 440 ft. Gage • 250		
ft. Gage	Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,	
	with at least one entry for each change of format position of Static Water Level and indicate prin	
PERFORATIONS: Perforated? A Yes \(\sigma\) No.	-	
Type of perforator used factory	MATERIAL	From To SWL
Size of perforations 1/8 in. by $2\frac{1}{2}$ in.	Top Soil	5 7
12800 perforations from 40 ft. to 400 ft.	Yellow Clay Cementatious sand & gravel	7 104
perforations from ft. to ft.	Blue Clay	104 217
perforations from	Coarse Black Sand	217 384
(7) SCREENS: Well screen installed? Yes No	Cementatious grave & Sand	384 409
Manufacturer's Name	Sandy Blue Clay	409 440
Type Model No.		
Diam Slot size Set from ft. to ft.		
Diam. Slot size Set from ft. to ft.		
(8) WELL TESTS: Drawdown is amount water level is		
Interstate		
Was a pump test made? 13 Yes No if yes, by whom? Pump		
Yield: 14.00 gal./min. with 180 ft. drawdown after hrs.	The second secon	
n H H		-
H H H	and the second second	
Bailer test gal./min. with ft. drawdown after hrs.		
Artesian flow g.p.m.		
perature of water Depth artesian flow encountered ft.	Work started 10/15/ 19 79 Complet	ed 6/10/80 19
(9) CONSTRUCTION:	Date well drilling machine moved off of well	6/11/80 ¹⁹
Coment Crosst	Drilling Machine Operator's Certification:	•
Well seal—Material used Cement Group Well sealed from land surface to	This well was constructed under my	direct supervision.
Diameter of well bore to bottom of seal 34 in.	Materials used and information reported best knowledge and bestef.	1
Diameter of well bore below sealin.	[Signed] Status	Date 4/15 198/
Number of sacks of cement used in well seal 10 Bolls sacks	Duilling Machine (Incretor)	
How was cement grout placed?Grout Pump	Drilling Machine Operator's License No. 314	
The state of the s	Water Well Contractor's Certification:	
A CONTRACTOR OF THE PROPERTY O	This well was drilled under my jurisdiction and this report is	
	true to the best of my knowledge and belief.	
Was a drive shoe used? Yes No Plugs Size: location ft.	Name 6 & C ENLOE DRILLING, INC. (Person, firm or corporation) (Type or print)	
Did any strata contain unusable water?	Address P.O. Box 323, Dorris, Ca. 96023	
Type of water? depth of strata	Address Address	
Method of sealing strata off	[Signed] Call (Water Well Contractor)	
Was well gravel packed? ★ Yes □ No Size of gravel: 3/8 to 3/4	The state of the s	معا مساء
Gravel placed from 9, to 440 ft.	Contractor's License No503 Date	7/ /2