NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT. SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 395/19E-11 Cd State Permit No. G-88-11

(1) OWNER:	(10) LOCATION OF WELL:
Name Steve Sherman	County Lake Driller's well number
Address Po. box 1104	
Lakeview Oregon 97630	Bearing and distance from section or subdivision corner
(2) TYPE OF WORK (check):	S Subdivision Control
New Well 🖾 Deepening 🗌 Reconditioning 🗌 Abandon 🗍	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	
Rotary Driven Domestic F Industrial D Municipal F	10 8/1/70
Cable	200 osow zana barracci. Date 7 7
The state of the s	Artesian pressure lbs. per square inch. Date
CASING INSTALLED: Threaded □ Welded ₺  " Diam. from 0 ft. to 60 ft. Gage .250  " Diam. from ft. to ft. Gage	(12) WELL LOG: Diameter of well below casing
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and structure of materials and show thickness and nature of each stratum and aquifer penetrated with at least one entry for each change of formation. Report each change in
PERFORATIONS: Perforated?   Yes   No.	position of Static Water Level and indicate principal water-bearing strata
Type of perforator used	MATERIAL From To SWL
Size of perforations in. by in.	sandy brown top soil 0 4
perforations from ft. to ft.	brown sand 4 50
perforations from ft. to ft.	medium sand 4 Gvave 50 61 19
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? ☐ Yes ☐ No	
Manufacturer's Name	
Type Model No	
Diam ft. to ft.	
Diam. Slot size Set from ft. to ft.	DEPENDEN.
(8) WELL TESTS: Drawdown is amount water level is	
lowered below static level	AUC 1:37079
Was a pump test made? ☐ Yes ☐ No If yes, by whom?	
Yield: gal./min. with ft. drawdown after hrs.	WATER RESOURCES DEPT
" "	SALEM, OREGON
" " "	
Bailer test 37 <sup>1</sup> / <sub>2</sub> gal./min. with 39 ft. drawdown after 1 hrs.	
Artesian flow g.p.m.	
perature of water 53 Depth artesian flow encountered ft.	Work started 7/31 1979 Completed 8/1 1979
(9) CONSTRUCTION:	
Well seal—Material used <u>CEMENT</u> Well sealed from land surface to \$6 47 ft	Drilling Machine Operator's Certification:
Well sealed from land surface to $\frac{10}{20}$ ft. Diameter of well bore to bottom of seal $\frac{10}{20}$ in.	This well was constructed under my direct supervision. Materials used and interpretation reported above are true to my
Diameter of well bore below seal	best knowledge and belief
Number of sacks of cement used in well seal 12 sacks	[Signed] Willing Machine Operator) Date 8/8 , 1979
How was cement grout placed?	Drilling Wachine Operator's License No. 1064
An amphilit of the	
The second secon	Water Well Contractor's Certification:
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? 🙀 Yes 🗌 No Plugs Size: location ft.	
Old any strata contain unusable water?   Yes   No	Name Sevey well drilling (Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 117 N.K Street Lakeview Oregon
Tethod of sealing strata off	18imas HO2 & Sound
as well gravel packed? Tyes No Size of gravel:	[Signed] (Water Well Contractor)
vel placed from ft. to ft.	Contractor's License No. 617 Date 8/8
the state of the s	1U