## WATER WELL REPORT

STATE OF OREGON



## JUN 17 1981

WATER RESOURCES DERT SALEM, OREGON

RECEIVED

State Permit No.

1) OWNER:	(10) LOCATION OF WELL:
Name BEN & NELDA MORRIS	County LAKE Driller's well number AR-(987)
Address	NE 4 NW4 Section 22 T. 395 R. 19 EW.M.
City LAKEVIEW, OREGON State 97630	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location:
New Well	
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
	Depth at which water was first found 125 ft.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level $12$ ft. below land surface. Date $11/3/80$
Rotary Air Driven Domestic Mandustrial Municipal Rotary Mud Mandustrial Dug Dirrigation Mandustrial Dother D	Artesian pressure lbs. per square inch. Date
Bored	(12) WELL LOG: Diameter of well below casing None
(5) CASING INSTALLED: Steel 🔀 Plastic 🗆	Depth drilled 200 ft. Depth of completed well 200 ft.
Threaded 🔲 Welded 🖂	Formation: Describe color, texture, grain size and structure of materials; and show
6 5/8 Diam from 0 ft to 200 ft Gauge 250	thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level
	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
	S Soil Zone (Sandy) 0 4
(6) PERFORATIONS: Perforated? X Yes  \( \text{No} \)	Clay (Blue to Grey) 4 125
Type of perforator used Factory Perforated Casing	Gravel (Fine, Blue), H20 Zone   125   128   12
Size of perforations $1/8$ in. by 3 in.	Clay & Sand Blue 128 140
1,200 perforations from 100 ft. to 200 ft.	Sand (Medium) & Gravel (Fine)
perforations from ft. to ft.	(Blue Color) 140 195
perforations from ft. to ft.	Clay (Blue) 195 200
(7) SCREENS: Well screen installed? ☐ Yes ※No	
Manufacturer's Name	
Type	
Diam. Slot Size Set from ft, to ft.	
Diam. Slot Size Set from ft. to ft.	
Drawdown is amount water level is lowered	
below static level	
Was a pump test made? A Yes  No If yes, by whom? Contractor	
s: 100 gal/min. with 20 ft. drawdown after 2 hrs.	
Air test 100 gal/min. with drill stem at 200 ft. 2 hrs.  Bailer test gal/min. with ft. drawdown after hrs.	
perature of water 640 Depth artesian flow encountered	
(0) (0) (0)	Work started 10/25/ 1980, Completed 11/3/1980
(9) CONSTRUCTION: Special standards: Yes □ No & Well seal—Material used	Date well drilling machine moved off of well 11/3/1980
Well seal—Material used Cement Bentonite Grout  Well sealed from land surface to 20 ft.	Drilling Machine Operator's Certification:
Diameter of well bore to bottom of seal	This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal	[Signed] Hay Stoot sterry Date 11/3/19 80
Number of sacks of cement used in well seal	(Drilling Machine Operator)
How was cement grout placed? A 1½ Inch Pipe was placed	Drilling Machine Operator's License No801.
along side casing and down to the 20 Ft.	Water Well Contractor's Certification:
level. Grout was then forced from bottom up.	This well was drilled under my jurisdiction and this report is true to
Was pump installed?NO	the best of my knowledge and belief. Name RAPID WATER WELL DRILLING CO.
Was a drive shoe used? ☐ Yes 🕅 No Plugs Size: location ft.	(Person, firm or corporation) (Type or print)
Did any strata contain unusable water?	Address P. O. BOX 750, Lakeview, Oregon 97630
Type of Water? depth of strata  Method of sealing strata off	[Signed] Lay Stook levy
Was well gravel packed? 2 Yes □ No Size of gravel: 1 10 14 1	(Water Well Contractor)
Gravel placed from 20 ft. to 200 ft.	Contractor's License No. 652 Date 11/3/, 1980