

RECEIVED
AUG 23 1961

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT

STATE OF OREGON

State Well No. 39/20-5D(1)

State Permit No. G 2099

(1) OWNER:

Name Favell-Utley Realty Co.
Address 120 No. E St.
Lakeview, Oregon

(2) LOCATION OF WELL:

County Lake Owner's number, if any—
1/4 1/4 Section 5 T. 39S R. 20E W.M.
Bearing and distance from section or subdivision corner
110'S 46'E of the NW corner of Sec. 5,
T.39S, R.20E 2 1/2 miles NW of
Lakeview, Oregon

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other
Stock Water

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
14" Diam. from 0 ft. to 165 ft. Gage 3/16
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used Mills
SIZE of perforations 1/4 in. by 3 in.
495 perforations from 40 ft. to 95 ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name
Type Model No.
..... Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: 1/4 to 3/4
Gravel placed from top ft. to 165 ft.
Was a surface seal provided? Yes No To what depth? ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level Artesian ft. below land surface Date 8/22/61
Artesian pressure Not known per square inch Date
Log Accepted by: Favell-Utley Realty Co.
[Signed] Robert C. Utley Date Aug. 22, 1961
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Driller

Was a pump test made? Yes No If yes, by whom? Driller
Yield: 600 gal./min. with 80 ft. drawdown after 24 hrs.

" " " "

" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow 60 g.p.m. Date 8/22/61

Temperature of water 50 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 14 inches.

Depth drilled 165 ft. Depth of completed well 165 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
top soil	0	4
large brown gravel	4	12
blue clay	12	18
large blue gravel	18	95
blue clay	95	100
blue sandy silt	100	165

Work started 8/14 1961. Completed 8/18 1961

(13) PUMP:

Manufacturer's Name
Type: H.P.

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Jack Stooksberry Jr.
(Person, firm, or corporation) (Type or print)

Address Rte. 2, Box 47, Lakeview, Ore.

Driller's well number B.H. #1

[Signed] Jack Stooksberry Jr.
(Well Driller)

License No. 211 Date 8/22, 1961