

RECEIVED
DEC 5 1961

Lake 2403

39/20 6 B(1)

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. _____

State Permit No. _____

(1) OWNER:

Name Favell-Utley Realty Co.
Address 120 E. Street north
Lakeview, Oregon

(2) LOCATION OF WELL:

County LAKE Owner's number, if any - B.U. #2
NW 1/4 NE 1/4 Section 6 T. 39s R. 20 E. W.M.
Bearing and distance from section or subdivision corner
184 ft South thence 64 feet East of the
northwest corner of the north east
quarter Sec. 6.

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
1 1/4" Diam. from 0 ft. to 210 ft. Gage 3/16
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used Mills
SIZE of perforations 1/4 in. by 3 in.
190 perforations from _____ ft. to _____ ft.
1 perforations from 190 ft. to 170 ft.
1 perforations from 130 ft. to 60 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: 3/4
Gravel placed from Top ft. to 210 ft.
Was a surface seal provided? Yes No To what depth? _____ ft.
Material used in seal—
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 0 ft. below land surface Date _____
Artesian pressure _____ lbs. per square inch Date _____
Log Accepted by: Favell-Utley Realty Co.
[Signed] A.C. Utley (Owner) Date Dec. 1, 1961

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? _____
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 1 1/4 inches.
Depth drilled 210 ft. Depth of completed well 210 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top soils	0	4
4 Brown Clay & Gravel	4	23
Gray Clay & Gravel	23	27
27 Gray clay with sand layers	27	130
Hard Clay	130	166
Loose Gravel	166	188
Sediment & sand	188	210

Work started Nov. 15 1961 Completed Nov. 30 1961

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Jack Stokesherry Jr.
(Person, firm, or corporation) (Type or print)

Address P.O. Box 47, Lakeview

Driller's well number _____

[Signed] Jack Stokesherry Jr.
(Well Driller)

License No. 211 Date Nov. 30, 1961