NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

Lake 2408

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED
NOV 22 1977
WATER RESOURCES DEPT.
SALEM, OREGON

State Well No. 39S/20E-7bb
State Permit No.

(1) OWNER:
Name Donald O. Shullanberger
Address Rt. 6
Lakeview, Oregon 97630

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒
24" Diam. from 0 ft. to 20 ft. Gage .250
16" Diam. from 0 ft. to 500 ft. Gage .250
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Factory
Size of perforations 1/8 in. by 2 1/4 in.
40' perforations from 500' ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Interstate Pump
Yield: 2250 gal./min. with 86 ft. drawdown after 40 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement Grout
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 30 in.
Diameter of well bore below seal 24 in.
Number of sacks of cement used in well seal 1 yd sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☒ Yes ☐ No Size of gravel: 3/8-3/4
Gravel placed from 0 ft. to 500 ft.

(10) LOCATION OF WELL:
County Lake Driller's well number 77-5
NE ¼ NW ¼ Section 7 T. 39S R. 20E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 8 ft.
Static level ft. below land surface. Date
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled 500 ft. Depth of completed well 500 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Top Soil	0	3	
Hard Pan	3	6	
Yellow Clay	6	26	
Alluvial fill			
varying sand & gravel			
& clay streaks	26'	500'	

Work started 10/6 19 77 Completed 11/2 19 77
Date well drilling machine moved off of well 11/5 19 77

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Carl F. Enlow (Drilling Machine Operator) Date 11/19, 19 77
Drilling Machine Operator's License No. 316

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name C & C Enlow Well Drilling Co. (Person, firm or corporation) (Type or print)
Address P.O. Box 323 Dorris, Ca.
[Signed] Carl V. Enlow (Water Well Contractor)
Contractor's License No. 503 Date 11/19, 19 77

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119