

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

RECEIVED

dd

STATE OF OREGON
(Please type or print)

MAY 17 1974

State Well No.

395/20E-9

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date
of well completion.

STATE ENGINEER
SALEM, OREGON

State Permit No.

(Do not write above this line)

(1) OWNER:

Name Lake County Fair Grounds
Address Lakeview, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 330 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used Factory Perforations

Size of perforations 3/32 in. by 3 in.
2400 perforations from 60 ft. to 320 ft.
perforations from ft. to staggered
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? Yes No If yes, by whom? Driller
Yield: 200 gal./min. with 83 ft. drawdown after 34 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water 52 Depth artesian flow encountered ft.

(9) CONSTRUCTION: 40' 18" conductor .375

Well seal—Material used Pressurized Cement Grout
Well sealed from land surface to 40 ft.
Diameter of well bore to bottom of seal 24 in.
Diameter of well bore below seal 16 in.
Number of sacks of cement used in well seal 38 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: 3/8
Gravel placed from 40 ft. to 330 ft.

(10) LOCATION OF WELL:

County Lake Driller's well number
W 1/2 SE 1/4 SE 1/4 Section 9 T. 39 SR. 20 E.W.M.
Bearing and distance from section or subdivision corner
1/2 mile due west of Lakeview, Oregon

(11) WATER LEVEL: Completed well.

Depth at which water was first found 45 ft.
Static level 12 ft. below land surface. Date 5/15/74
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 16"

Depth drilled 330 ft. Depth of completed well 330 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Soil Zone (adobe)	0	2	
Clay (brown)	2	10	
Clay (blue)	10	45	12
Gravel (blue, medium)	45	55	
Sand (grey, fine)	55	65	
Clay (blue, sandy)	65	80	
Boulders & Clay (blue)	80	112	
Clay (blue)	112	145	
Clay & Gravel (blue, fine)	145	180	
Sand (fine, blue)	180	187	
Clay (blue)	187	270	
Gravel (blue, fine)	270	320	
Clay (blue)	320	330	

Work started 4/17/ 19 74 Completed 5/15/ 19 74

Date well drilling machine moved off of well 5/17/ 19 74

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] Gary Stooksberry Date 5/15/ 19 74
(Drilling Machine Operator)

Drilling Machine Operator's License No. 801

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name Jack Stooksberry, Jr.
(Person, firm or corporation) (Type or print)

Address Rt. 2 Box 47, Lakeview, Oregon

[Signed] Jack Stooksberry Jr.
(Water Well Contractor)

Contractor's License No. 211 Date 5/15/ 19 74