

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT

JUL 2 1965 STATE OF OREGON
(Please type or print)

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE ENGINEER

Radio Co. Well #

cb2

State Well No. 39/20-15 AA

State Permit No. _____

G-3779

(1) OWNER: SALEM, OREGON
Name Town of Lakeview
Address Lakeview, Oregon

(2) LOCATION OF WELL:
County Lake Driller's well number _____
NW 1/4 SW 1/4 Section 15 T. 39 S R. 20 E W.M.
Bearing and distance from section or subdivision corner
1/2 mi. West of Lakeview from Hwy. 395

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded
14" Diam. from 0 ft. to 390 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used factory perforated pipe
Size of perforations 3/16 in. by 2 in.
~~2400~~ perforations from _____ ft. to _____ ft.
4200 perforations from 100 ft. to 240 ft.
1200 perforations from 300 ft. to 340 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Well seal—Material used in seal cement
Depth of seal 40 ft. Was a packer used? yes
Diameter of well bore to bottom of seal 24 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: 3/8 to 1"
Gravel placed from 40 ft. to 390 ft.
Did any strata contain unusuable water? Yes No
Type of water? surface depth of strata 5'
Method of sealing strata off cement

(10) WATER LEVELS:
Static level 32 ft. below land surface Date 7/1/65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Contractor
Yield: 850 gal./min. with 133 ft. drawdown after 24 hrs.
" efficiency of well 500" g.p.m. "
" with 100" pumping level "
Baller test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 62 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 24"
Depth drilled 405 ft. Depth of completed well 390 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
soil zone, sandy	0	12
gravel & clay, med. brn.	12	45
clay, brn.	45	90
gravel & sand, med.	90	125
clay & gravel, brn.	125	135
sandy clay, blue	135	155
clay & gravel, med. blue	155	162
gravel & clay, loose stringers	162	190
gravel, lge.	190	195
clay & gravel	195	310
gravel & sand, loose	310	325
clay & gravel, blue	325	385
boulders	385	395
clay, blue	395	405
water bearing formations	90	120
" " " "	310	325

diameter of well 24" with 14" casing installed to provide space for gravel packing

Work started 5/17 1965 Completed 6/30 65
Date well drilling machine moved off of well 6/30 65

(13) PUMP:
Manufacturer's Name Western Pump Co.
Type: Water lubricated turbine P. 60

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Jack Stooksberry Jr.
(Person, firm or corporation) (Type or print)
Address Rte. 2, Box 47, Lakeview, Ore.
Drilling Machine Operator's License No. 45

[Signed] _____
(Water Well Contractor)
Contractor's License No. 211 Date July 1, 1965