NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT F C E IV FOR STATE OF OREGON

(Please type or print)

(Do not write above this line) TER RESOURCES DEPT.

(1) OWNER:	(10) LOCATION OF WELL:		
Name Town of Lakeview	County Lake Driller's well number		
Address Lakeview, Oregon 97630	NW 14 NW 14 Section 16 T.39S	r. 20	W.M.
	Bearing and distance from section or subdivision corner		
(2) TYPE OF WORK (check):	1 mile west of Lakeview on Hwy. 140		
New Well KK Deepening □ Reconditioning □ Abandon □			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	الم	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 70 ft.		
Determine The Determine I'm	Static level 55 ft. below land surface. Date 7/6/76		
Cable			
Dug Bored Irrigation Test Well Other	Artesian pressure lbs. per squar	e inch. Dat	:e
CASING INSTALLED: Threaded Welded XX 12 "Diam from 0 ft to 371 ft Gage 250 "Diam from ft to ft Gage	(12) WELL LOG: Diameter of well below casing9		
"Diam. fromft. toft. Gage	Formation: Describe color, texture, grain size a and show thickness and nature of each stratur with at least one entry for each change of formations.	n and aquif	er penetrated,
PERFORATIONS: Perforated? XXYes No.	position of Static Water Level and indicate prin	cipal water-	bearing strata.
Type of perforator used factory mill cut	MATERIAL	From	To SWL
Size of perforations 1/8 in. by 3 in.	soil zone, heavy		ł
7200 perforations from	sandy clay, brown		12
perforations from ft. to ft.	gravel, med., brn.		30
perforations from ft. to ft.	clay, blk. to green	_	12
(7) SCREENS: Well screen installed? ☐ Yes ☒ No	clay, blue		50
Manufacturer's Name	clay & gravel, blue gravel, fine, blue		70 77 55
Type Model No.	sandy clay, blue	. , , ,	158
Diam Slot size ft. to ft.	gravel, fine, blue	1 ' ' 1	170
Diam. Slot size from ft. to ft.	clay, blue		280
(8) WELL TESTS. Drawdown is amount water level is	cemented gravel w/loose		
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	stratas in void areas	280	305
Was a pump test made? K Yes □ No If yes, by whomuriller	clay, blue to black	305 4	100
d: 1200 gal./min. with 55 ft. drawdown after 119 hrs.	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	<u> </u>	
и и	***	<u> </u>	
" " "			
Bailer test gal./min. with ft. drawdown after hrs.			
sian flow g.p.m.			
nperature of water 58 Depth artesian flow encountered ft.	Work started 5/18 19 76 Complete	ed 7/6	5 1976
(9) CONSTRUCTION:	Date well drilling machine moved off of well	7/0	6 1976
	Delilling Machine Operator's Certification:		
Well sealed from land surface to 40 w/24" con-ft. Diameter of well bore to bottom of seal 32 in. Diameter of well bore below seal 24 in.	This well was constructed under my Materials used and information reported best knowledge and belief.	above are	true to my
Number of sacks of cement used in well seal sacks	[Signed] ach Hooksberry Date 7/6, 19.76		
Number of sacks of bentonite used in well sealsacks	Drilling Machine Operator's License No	45	**********************
Brand name of bentonite		 -	
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:		
of waterlbs./100 gals.	This well was drilled under my jurisdiction and this report is		
Was a drive shoe used? ☐ Yes 🌣 No Plugs Size: location ft.	true to the best of my knowledge and belief. Name Jack Stooksberry, Jr.		
Did any strata contain unusable water? Yes No	(Person, firm or corporation) (Type or print)		
Type of water? depth of strata	Address Rte. 2, Box 47, Lakeview, OR 97630		
Method of sealing strata off	Issued Och Pt D. A.	0-	
Was well gravel packed? X Yes □ No Size of gravel 3/8	[Signed] (Water Well Contr	actor)	
Gravel placed from 40 ft. to 371 ft.	Contractor's License No. 211 Date	7/6	, 1976