

The original and first copy of this report are to be filed with the

RECEIVED

STATE OF OREGON

RECEIVED

State Well No.

395/20E-20a

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

MAY 07 1977

(Please type or print)

MAY - 9 1977

State Permit No.

WATER RESOURCES DEPT.

SALEM, OREGON

(10) LOCATION OF WELL:

(1) OWNER:

SALEM, OREGON

Name Lakeview School Dist No. 7
Address P.O. Box 1069
Lakeview Oregon 97630

County Lake
Driller's well number
1/4 NE 1/4 Section 20 T. 39S R. 20E W.M.

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

(4) PROPOSED USE (check):

Rotary [X] Driven [] Cable [] Jetted [] Dug [] Bored []
Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(11) WATER LEVEL: Completed well.

Depth at which water was first found 6 ft.

Static level 10 ft. below land surface. Date

Artesian pressure lbs. per square inch. Date

(6) CASING INSTALLED:

Threaded [] Welded []

12 4" Diam. from 0 ft. to 500 ft. Gage .250

(8) PERFORATIONS:

Perforated? [X] Yes [] No.

Type of perforator used Factory
Size of perforations 3/16 in. by 2 1/2 in.
24 per ft perforations from 40 ft. to 500 ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Interstate

Was a pump test made? [X] Yes [] No If yes, by whom? Pump

Yield: gal./min. with ft. drawdown after hrs.
Copy Enclosed, " "

Baller test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.

Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement pressure Grout
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 30 in.
Diameter of well bore below seal 22 in.
Number of sacks of cement used in well seal 1 yd & 1/4 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? [] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [X] Yes [] No Size of gravel: 3/8 to 3/4
Gravel placed from 0 ft. to 500 ft.

(12) WELL LOG:

Diameter of well below casing

Depth drilled 500 ft. Depth of completed well 500 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with 4 columns: MATERIAL, From, To, SWL. Rows include Top Soil, Sandy Clay & Gravel, Blue Green Clay, Sandy Clay, More Sand than Clay, Small gravel & Clay, Sandy Clay, Cementitious gravel.

Work started 3/28/77 19 Completed 4/23/77 19

Date well drilling machine moved off of well 4/23/77 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] P.S. Enloe Date 5/1, 1977 (Drilling Machine Operator)

Drilling Machine Operator's License No. 316

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name C & C Enloe Drilling (Person, firm or corporation) (Type or print)
Address P.O. Box 323, Dorris, Ca. 96023

[Signed] Carl W. Enloe (Water Well Contractor)

Contractor's License No. 503 Date 5/1, 1977

Interstate PUMP COMPANY, INC.

503,882-3464 — 7209 SOUTH SIXTH STREET
KLAMATH FALLS, OREGON 97601

WELL TEST REPORT

For: C & C Enloe Well Drilling

Date Tested April 21, 22, 23, 19 77

(Page 1 of 5)

Dorris, California 96023

Location of Well Lakeview (Future Farmers of America)

Inside Diameter 12" Depth _____

Feet of _____ Inch Casing. Driller _____

200 Feet of 8 Inch Column and 5 Stage 10 Inch Bowls.
100 Ft. 9" Tail Pipe

Test Done By Mike Campbell, Fred Singleton, Lee Campbell

Static Water Level at Start of Test 10 Ft.

CAPACITY GPM	PUMPING LEVEL	DRAWDOWN	TIME	CONDITION OF WATER (SANDY, MUDDY, CLEAR, ETC.)
<u>4/21/77</u>	<u>Started Test</u>		<u>2:30P</u>	
<u>700</u>	<u>165 Ft.</u>	<u>155 Ft.</u>	<u>2:45P</u>	<u>Heavy Black Sand</u>
<u>1000</u>	<u>165 Ft.</u>	<u>155 Ft.</u>	<u>3:00P</u>	" " "
<u>1200</u>	<u>155 Ft.</u>	<u>145 Ft.</u>	<u>3:30P</u>	" " "
<u>1200</u>	<u>155 Ft.</u>	<u>145 Ft.</u>	<u>4:00P</u>	" " "
<u>1200</u>	<u>155 Ft.</u>	<u>145 Ft.</u>	<u>4:30P</u>	" " "
<u>1200</u>	<u>155 Ft.</u>	<u>145 Ft.</u>	<u>5:00P</u>	" " "
<u>1200</u>	<u>155 Ft.</u>	<u>145 Ft.</u>	<u>5:30P</u>	" " "
<u>1325</u>	<u>168 Ft.</u>	<u>158 Ft.</u>	<u>6:00P</u>	" " "
<u>1325</u>	<u>168 Ft.</u>	<u>158 Ft.</u>	<u>6:30P</u>	" " "
<u>1325</u>	<u>168 Ft.</u>	<u>158 Ft.</u>	<u>7:00P</u>	" " "
<u>1325</u>	<u>168 Ft.</u>	<u>158 Ft.</u>	<u>7:30P</u>	" " "
<u>1325</u>	<u>168 Ft.</u>	<u>158 Ft.</u>	<u>8:00P</u>	" " "
<u>1325</u>	<u>168 Ft.</u>	<u>158 Ft.</u>	<u>8:30P</u>	" " "
<u>1325</u>	<u>168 Ft.</u>	<u>158 Ft.</u>	<u>9:00P</u>	" " "
<u>1325</u>	<u>168 Ft.</u>	<u>158 Ft.</u>	<u>9:30P</u>	" " "
<u>1325</u>	<u>168 Ft.</u>	<u>158 Ft.</u>	<u>10:00P</u>	" " "
<u>1325</u>	<u>168 Ft.</u>	<u>158 Ft.</u>	<u>10:30P</u>	" " "
<u>1325</u>	<u>168 Ft.</u>	<u>158 Ft.</u>	<u>11:00P</u>	" " "
<u>1325</u>	<u>168 Ft.</u>	<u>158 Ft.</u>	<u>12:00Mid.</u>	" " " & grey clay
				TEMPERATURE _____

Static Water Level After Pump Removed _____

REMARKS: _____

Signed by _____

WELL TEST REPORT

Interstate PUMP COMPANY, INC.

503,862-3464 — 7202 SOUTH SIXTH STREET
 KLAMATH FALLS, OREGON 97601

For: C. & C. Enloe Well Drilling

Date Tested April 21, 22, 23, 19 77

Dorris, California 96023

(Page 2 of 5)

Location of Well Lakewiew (Future Farmers of America)

Inside Diameter 12" Depth _____

Feet of _____ Inch Casing. Driller _____

200 Feet of 8 Inch Column and 5 Stage 10 Inch Bowls.
100 Ft. 9" Tail pipe

Test Done By Mike Campbell, Fred Singleton, Lee Campbell

Static Water Level at Start of Test 10 Ft.

CAPACITY GPM	PUMPING LEVEL	DRAWDOWN	TIME	CONDITION OF WATER (SANDY, MUDDY, CLEAR, ETC.)
1325	168 Ft.	158 Ft.	1:AM	Heavy Black Sand - Grey clay
1325	168 Ft.	158 Ft.	2:00 A	" " " " "
1325	165 Ft.	155 Ft.	3:00A	Clearing a little - Otherwise the same
1325	165 Ft.	155 Ft.	4:00A	" " " " "
1325	165 Ft.	155 Ft.	5:00A	Black sand - grey clay - Clearing
1325	165 Ft.	155 Ft.	6:00A	" " " " *Almost Clear
	Surged -	Gravel didn't	go down	
1325	160 Ft.	150 Ft.	7:00A	Clearing a little added 100FPM
1495	155.5 Ft.		7:20A	Clearing a little
1495	154 Ft.	144 Ft.	8:00A	Clearing some
	Surged -	Gravel went 1	Yd.	
1495	154 Ft.		8:30A	Black sand & grey clay
1540	163 Ft.		9:00A	" " " " Clearing
1540	166 Ft.		9:30A	" " " " "
1500	167 Ft.		10:00A	Gravel went (15 Yds.)
1500	167 Ft.		10:30A	Heavy black sand - clearing
1500	167 Ft.		11:30A	" " " " "
1350	150 Ft.	140 Ft.	12:00 Noon	Heavy Black sand
1350	150 Ft.	140 Ft.	12:30P	" " " " "
1350	150 Ft.	140 Ft.	1:00P	Medium sand
				TEMPERATURE _____

Static Water Level After Pump Removed _____

REMARKS: _____

Signed by _____

Interstate PUMP COMPANY, INC.

503-882-3463 -- 7209 SOUTH SIXTH STREET
KLAMATH FALLS, OREGON 97601

WELL TEST REPORT

For: C. C. Enloe Well Drilling

Date Tested April 21, 22, 23, 1977

Dorris, California 96023

(Page 3 of 5)

Location of Well Lakeview (Future Farmers of America)

Inside Diameter 12" Depth _____

Feet of _____ Inch Casing. Driller _____

200 Feet of 8 Inch Column and 5 Stage 10 Inch Bowls.

Test Done By Mike Campbell, Fred Singleton, Leo Campbell

Static Water Level at Start of Test 10 Ft.

CAPACITY GPM	PUMPING LEVEL	DRAWDOWN	TIME	CONDITION OF WATER (SANDY, MUDDY, CLEAR, ETC.)
1495	156 Ft.	146 Ft.	2:00P	Medium Sand
	Surged (shut off)		Gravel went down	(2Yds)
1550	154 Ft.	144 Ft.	3:00P	Grey clay small Black sand
1710	163 Ft.	153 Ft.	4:00P	Clearing
	Surged - 30 Min.		Gravel went down	(5Yards)
1710	164 Ft.	154 Ft.	5:00P	Clearing
1600	158 Ft.	148 Ft.	6:00P	"
1600	160 Ft.	150 Ft.	7:00P	"
1575	160 Ft.	150 Ft.	8:00P	"
1550	160 Ft.	150 Ft.	8:30P	"
1550	162 Ft.	152 Ft.	9:00P	"
1550	162 Ft.	152 Ft.	9:30P	Clearing - Light sand & clay
1550	163 Ft.	153 Ft.	10:00P	" " " "
1550	163 Ft.	153 Ft.	10:30P	" " " "
1550	164 Ft.	154 Ft.	11:00P	" - Light clay
	Surged - 30 Min-	No gravel		
4/23/77 1550	164 Ft.	154 Ft.	12:30A	Light sand and clay
1710	170 Ft.	160 Ft.	1:30A	" " "
1710	173 Ft.	163 Ft.	2:00A	Clearing very light sand and clay
1710	174 Ft.	164 Ft.	2:30A	Clear - very light clay
1710	175 Ft.	165 Ft.	3:00A	" TEMPERATURE " "

Static Water Level After Pump Removed _____

REMARKS: _____

Signed by _____

Interstate PUMP COMPANY, INC.

503-882-3464 — 7209 SOUTH SIXTH STREET,
KLAMATH FALLS, OREGON 97601

WELL TEST REPORT

For: G. & C. Enloe Well Drilling

Date Tested April 21, 22, 23 19 77

Dorris, California 96023

(Page 4 of 5)

Location of Well Lakeview (Future Farmers of America)

Inside Diameter 12" Depth _____

Feet of _____ Inch Casing. Driller _____

200 Feet of 8 Inch Column and 5 Stage 10 Inch Bowls.

100 Ft. 9" Tail Pipe

Test Done By Mike Campbell, Fred Singleton, Lee Campbell

Static Water Level at Start of Test 10 Ft.

CAPACITY GPM	PUMPING LEVEL	DRAWDOWN	TIME	CONDITION OF WATER (SANDY, MUDDY, CLEAR, ETC.)
1710	175 Ft.	165 Ft.	3:30A	Clear - Very light clay
1710	176 Ft.	166 Ft.	4:00A	" " " "
1710	176 Ft.	166 Ft.	4:30A	" " " "
1710	177 Ft.	167 Ft.	5:00A	Clearing
1710	177 Ft.	167 Ft.	5:30A	Clearing (Light Mud)
1710	178 Ft.	168 Ft.	6:00A	" " "
1710	178 Ft.	168 Ft.	6:30A	" " "
1710	179 Ft.	169 Ft.	7:00A	" " "
1710	179 Ft.	169 Ft.	7:30A	" " "
1950	183 Ft.	173 Ft.	8:00A	Clearing - Surged
1950	183 Ft.	173 Ft.	9:00A	Black sand & gray clay
1950	183 Ft.	173 Ft.	10:00A	Clearing to almost clear
<u>Draw down curve</u>				
1950	183 Ft.	173 Ft.	10:15A	Clear (small grey clay
1750	180 Ft.	170 Ft.	10:30A	" " " "
1625	172 Ft.	162 Ft.	10:45A	Clear
1400	165 Ft.	155 Ft.	11:00A	"
1250	151 Ft.		12:00 Noon	"
1250	154 Ft.	144 Ft.	1:00P	"
1250	154 Ft.	144 Ft.	2:00P	"
1250	154 Ft.	144 Ft.	3:00P	"
				TEMPERATURE _____ °

Static Water Level After Pump Removed _____

REMARKS: _____

Signed by _____

Interstate PUMP COMPANY, INC.

503/882-3464 — 7209 SOUTH SIXTH STREET
KLAMATH FALLS, OREGON 97601

WELL TEST REPORT

For: C. & C. Enloe Well Drilling

Date Tested April 21, 22, 23, 1977
(Page 5 of 5)

Dorris, California 96023

Location of Well Lakeview (Future Farmers of America)

Inside Diameter 12" Depth _____

Feet of _____ Inch Casing. Driller _____

200 Feet of _____ 8 Inch Column and 5 Stage 10 Inch Bowls.
100 Ft. 9" Tail Pipe

Test Done By Mike Campbell, Fred Singleton, Lee Campbell

Static Water Level at Start of Test 10 Ft.

CAPACITY GPM	PUMPING LEVEL	DRAWDOWN	TIME	CONDITION OF WATER (SANDY, MUDDY, CLEAR, ETC.)
1250	154 Ft.	144 Ft.	4:00P	Clear
1250	154 Ft.	144 Ft.	5:00P	"
1250	154 Ft.	144 Ft.	6:00P	"
1250	154 Ft.	144 Ft.	7:00P	"
1250	154 Ft.	144 Ft.	8:00P	"
1250	154 Ft.	144 Ft.	9:00P	"
1250	154 Ft.	144 Ft.	10:00P	"
1250	154 Ft.	144 Ft.	10:30P	"
Shut off - No gravel down				
56 Hrs. Total Test				
				TEMPERATURE <u>70</u> °

Static Water Level After Pump Removed _____

REMARKS: _____

Signed by _____