

RECEIVED

Lake 2677

NOTICE TO WATER WELL CONTRACTOR JUL 5 1968 WATER WELL REPORT STATE ENGINEER OF OREGON SALEM, OREGON

State Well No. 39/24-21 L State Permit No.

(1) OWNER:

Name School District #21 Address Adel, Oregon

(2) LOCATION OF WELL:

County Lake Driller's well number N.E. 1/4 S.W. 1/4 Section 21 T. 39 S. R. 24 E. W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [x] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [] 6" Diam. from 0 ft. to 123 ft. Gage 1/4"

(7) PERFORATIONS:

Perforated? [x] Yes [] No Type of perforator used Saw Cut Size of perforations 3 in. by 1/8 in. 120 perforations from 93 ft. to 103 ft.

(8) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement Depth of seal 18' ft. Was a packer used? Yes Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [x] Yes [] No Was well gravel packed? [x] Yes [] No Size of gravel: 1/4 to 3/4 Gravel placed from 18 ft. to 113 ft. Did any strata contain unusuable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 56 ft. below land surface Date 6-7-68 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [x] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Baller test 24 gal./min. with 6 ft. drawdown after 2 hrs. Artesian flow g.p.m. Date Temperature of water 60 Was a chemical analysis made? [] Yes [x] No

(12) WELL LOG:

Diameter of well below casing None Depth drilled 123 ft. Depth of completed well 123 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Soil Zone, Coarse Gravel Loose, Soft Sandy Clay Brown, Coarse Sand & Water Seep, Soft Sandy Clay Blue, Fine Gravel & Good Water, Soft Sandy Clay Brown, Hard Clay & Gravel Blue.

Work started 5-13 1968. Completed 6-7- 19 68 Date well drilling machine moved off of well 6-8- 19 68

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Jack Stooksberry Jr. (Person, firm or corporation) (Type or print)

Address Rt. 2 Box 47 Lakeview, Oregon

Drilling Machine Operator's License No. 391

[Signed] Jack Stooksberry Jr. (Water Well Contractor)

Contractor's License No. 211. Date 7-1, 1968