NOTICE TO WATER WELL CONTRACTOR The original and first copy WATER WELL REPORT CEIVED WELL NO. 405 19E-6 db of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 O within 30 days from the date of well completion.

(Please type or print)
(Do not write above this line)

DEC 301976 State Permit No. WATER RESOURCES DEPT.

1) OWNER:	(10) LOCALIUN CREGONLL:
Tame Jack Albertson	County Lake Driller's well number
ddressRt. 6 Box 466	NW 14 SE 14 Section 6 T. 408 R. 19E W.M.
Lakeview Or. 97630	Bearing and distance from section or subdivision corner
2) TYPE OF WORK (check):	
Iew Well □ Deepening ★ Reconditioning ★ Abandon □	
f abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found Exist. SWL 12 ft.
otary Driven Domestic Industrial Municipal	Static level 72 ft. below land surface. Date 75.2.7
dable	Artesian pressure lbs. per square inch. Date
	Artesian pressure ibs. per square men. Date
CASING INSTALLED: Threaded □ Welded □	(12) WELL LOG: Diameter of well below casing8!!
M.A. "Diam. from ft. to ft. Gage	Depth drilled 442 ft. Depth of completed well 442 ft.
	Formation: Describe color, texture, grain size and structure of materials;
" Diam, from ft. to ft. Gage	and show thickness and nature of each stratum and aquifer penetrated,
PERFORATIONS: Perforated? Yes X No.	with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.
Type of perforator used	MATERIAL From To SWL
	Sand Black Coarse 368 369 12 Rock Black Hard 369 442 12
perforations fromft. toft.	nock black naru 1009 442 12
perforations fromft. toft.	
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? Yes X No	
Manufacturer's Name	
Type Model No	
Diam Slot size Set from ft. to ft.	
Diam Slot size Set from ft. to ft.	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? XXVes No If yes, by whom? Volley Plans	
Vield:/600 gal./min. with 7 ft. drawdown after 2 hrs.	·
, , , , , , , , , , , , , , , , , , , ,	
n n n	
Bailer test gal./min. with ft. drawdown after hrs.	
Artesian flow g.p.m.	
aperature of water Depth artesian flow encountered ft.	Work started 11-30 1976 Completed 12-2 1976
(9) CONSTRUCTION:	Date well drilling machine moved off of well 12-2 1976
Well seal-Material used Already Completed	Drilling Machine Operator's Certification:
Well seal—Material used	This well was constructed under my direct supervision.
Diameter of well bore to bottom of seal in.	Materials used and information reported above are true to my best knowledge and belief.
Diameter of well bore below seal in.	
Number of sacks of cement used in well seal sacks	[Signed] Lam lucy Date , 136
Number of sacks of bentonite used in well seal sacks	Drilling Machine Operator's License No. 196
Brand name of bentonite	Water Well Contractor's Contifications
Number of pounds of bentonite per 100 gallons	Water Well Contractor's Certification:
of water	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Was a drive shoe used? 🗆 Yes 🛣 No Plugs Size: location ft.	Name Sevey Welldrilling
Did any strata contain unusable water? [] Yes D No	(Person, firm or corporation) (Type or print)
Type of water? depth of strata	Address 117 N.K. Lakeview Or. 97630
Method of sealing strata off	[Signed] All Lavey
Was well gravel packed? [] Yes [] No Size of gravel:	(Water Well Contractor)
Gravel placed from ft to ft.	Contractor's License No. 617 Date 12-28, 1976