

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT.
SALEM, OREGON 97310
within 30 days from the date
of well completion.

LAKE 2834 WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 405/205-2a

State Permit No. _____

(1) OWNER:

Name Francis McNeley
Address Box 426
Lakeview OR

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cased ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒
6" Diam. from 1 ft. to 257 ft. Gage 280
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used _____

Size of perforations	in. by	in.
perforations from _____	ft. to _____	ft.
perforations from _____	ft. to _____	ft.
perforations from _____	ft. to _____	ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

" " " " " "

" " " " " "

Pump test 50 gal./min. with 89 ft. drawdown after 1 hrs.

Artesian flow _____ g.p.m.

Temperature of water 66 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 28 sacks
How was cement grout placed? pumped

Was a drive shoe used? ☒ Yes ☐ No Plugs _____ Size: location _____ ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Lake Driller's well number _____
E 1/4 NE 1/4 Section 2 T. 40S R. 20E W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 260 ft.

Static level 11 ft. below land surface. Date _____

Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6

Depth drilled 285 ft. Depth of completed well 285 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Clay hard Brown Bpsol	0	5	
Clay & gravel Brown	5	20	
Clay Brown	20	35	
Clay & gravel Brown	35	42	
Clay Brown	42	56	
Clay & gravel Brown	56	57	
Conglomerate Rock Brown	57	285	11
(S&T)			

RECEIVED

NOV - 8 1979

WATER RESOURCES DEPT
SALEM, OREGON

Work started 10-10 1979 Completed 10-18 1979

Date well drilling machine moved off of well 10-18 1979

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] Oregon Chancell Date 11-3, 1979
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1064

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name Sewer Well Drilling
(Person, firm or corporation) (Type or print)

Address 117 N. K. 440. OR.

[Signed] Glen L. Sewer
(Water Well Contractor)

Contractor's License No. 617 Date 10-31, 1979