NOTICE TO WATER WELL CONTRACTOR

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

2018

WATER WELL REPORTE GEIVED
STATE OF OREGON JUL 30 1968 at Dell No. 41/16-1 N

(Please type or print)
(Do not write above the sine TE ENGINEER it No. ...
SALEM OREGON

(1) OWNER:	(11) LOCATION OF WELL:	
Name Leo Albertson	County lake Driller's well number	
Address Rte. 6. Box 470. Lakeview. Ore.	1 SW 4 SW 4 Section 1 T. 41SR. 16E	W.M.
	Bearing and distance from section or subdivision corner	
(2) TYPE OF WORK (check):	35 miles SW of Lakeview, Oregon in	J
New Well 🗓 Deepening 🗌 Reconditioning 🗍 Abandon 🗍	Yokum valley	
If abandonment, describe material and procedure in Item 12.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(12) WELL LOG: Diameter of well below casing	16
Rotary Driven Domestic Industrial Municipal Domestic Municipal Domestic	Depth drilled 170 ft. Depth of completed well 170	
Dug		
CASING INSTALLED: Threaded Welded 15 16 "Diam from 0 ft to 60 ft Gage 250	Formation: Describe color, texture, grain size and structure of rand show thickness and nature of each stratum and aquifer per with at least one entry for each change of formation. Report each in position of Static Water Level as drilling proceeds. Note drilling	netrated, h change
	MATERIAL From To	swL
	soil zone, cinders red	
DEDECOR A MICONG.	fine 0 4	
PERFORATIONS: Perforated? 🖫 Yes 🗆 No.	cinders, coarse, red 4 53	
Type of perforator used Mills	water zone	
Size of perforations $\frac{1}{4}$ X3 in. by in.	basalt rock, gray 53 78	
250perforations from35ft. to60ft.	soft hasalt rock with	
perforations from ft. to ft.	crevices water zone 78 168	
perforations from ft. to ft.	hard basalt rock, gray	
perforations from ft. to ft.	to black 168 170	
perforations from ft. to ft.		
(7) SCREENS: Well screen installed? Well screen installed? Yes No		
Type		
Diam. Slot size Set from ft. to ft.		<u> </u>
Diam. Slot size Set from ft. to ft.		<u> </u>
· · · · · · · · · · · · · · · · · · ·		
(8) WATER LEVEL: Completed well.		
Static level 13 ft. below land surface Date $7/22/68$		
esian pressure lbs. per square inch Date		
(9) WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made? ☑ Yes ☐ No If yes, by whom? COntractor	Work started 7/16 19 68 Completed 7/23	19 50
wield: 1600 gal./min. with 14 ft. drawdown after 24 hrs.		19 68
" "	Date well drilling machine moved off of well 8/1	19 68
" " " "	Drilling Machine Operator's Certification:	
Bailer test gal./min. with ft. drawdown after hrs.	This well was constructed under my direct supervision rials used and information reported above are true to	
Artesian flow g.p.m. Date	knowledge and belief.	•
Temperature of water 44 Was a chemical analysis made? ☐ Yes ∑ No	[Signed] ach Abolivery n Date 8/1.	, 196.8
(10) CONSTRUCTION: Well seal—Material usedpuddled_clay	Drilling Machine Operator's License No. 45	
Depth of seal 20 t ft.	Water Well Contractor's Certification:	
Diameter of well bore to bottom of sealin.	This well was drilled under my jurisdiction and this	report is
Were any loose strata cemented off? Yes \ No Depth	true to the best of my knowledge and belief.	-
Was a drive shoe used? Tyes \(\) No	NAME Jack Stooksberry, Ir. (Type or print	·
Did any strata contain unusable water? Yes I No		~
Type of water? depth of strata	Address Rte. 2, Box 47, Lakeview, O	re.
Method of sealing strata off	The state of the s	
	[Signed] (Water Well Contractor)	
Was well gravel packed? Yes To No Size of gravel:	Contractor's License No.211 Date 8/1	10 60
Gravel placed from ft. to ft.	Contractor's License No.211 Date	, 19(ఎ.ద