WATER WELL REPORT STATE OF OREGON



RECEIVED

OCT - 2 1985

WATER RESOURCES DEPT

State Well No. 4/5/2

State Permit No.

SMAT . STEGON

(1) OWNER:	(10) LOCATION OF WELL: 376-85-11
Name Dept. Of General Serv. Ore. State	County Lake Driller's well number 6-11-85
Address 1230 State Street	NE 4 SE 4 Section 23 T. 41S R. 20E W.M.
City Salem, State Or.	Tax Lot # Lot Blk Subdivision
(2) TYPE OF WORK (check):	Address at well location: Goose Lake State Park
New Well □ Deepening □ Reconditioning ☑ Abandon □	Maintence Area
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.
	Depth at which water was first found 15 ft.
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Static level 15 ft. below land surface. Date 9-3-85
Rotary Air Driven Domestic Industrial Municipal Rotary Mud Dug Irrigation Test Well Other	Artesian pressure lbs. per square inch. Date
Cable 🖔 Bored 🗆 Thermal: Withdrawal 🗆 Reinjection 🗆	(12) WELL LOG: Diameter of well below casing
(5) CASING INSTALLED: Steel Plastic	Depth drilled ft. Depth of completed well 100 ft.
Threaded	Formation: Describe color, texture, grain size and structure of materials; and show
	thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level
	and indicate principal water-bearing strata.
LINER INSTALLED:	MATERIAL From To SWL
	Ref: Drillers log # 6-11-85
(6) PERFORATIONS: Perforated? Yes No	376-85-11
Type of perforator used	game and managed Carell
Size of perforations in. by in.	screens removed & well caved to bottom of 6"
perforations from ft. to ft.	
perforations from ft. to ft.	liner 100 15
perforations from ft. to ft.	
(7) SCREENS: Well screen installed? Yes No	
Manufacturer's Name	
Type Model No.	
Diam. Slot Size Set from ft. to ft.	
Diam. Slot Size Set from ft. to ft. On When I direction Drawdown is amount water level is lowered	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	
Was a pump test made? ☐ Yes ☒ No If yes, by whom?	
d: gal./min. with ft. drawdown after hrs.	
J11 " " " " " " " " " " " " " " " " " "	
Air test gal./min. with drill stem at ft. hrs.	
Bailer test 15 gal./min. with 20 ft. drawdown after 1 hrs.	
Artesian flow g.p.m.	
perature of water 540 Depth artesian flow encountered ft.	Work started 9-3 1985 Completed 9-3 1985
(9) CONSTRUCTION: Special standards: Yes \(\text{No} \(\text{I} \)	Date well drilling machine moved off of well 9-3 19 85
Well seal—Material used undistrubed	Drilling Machine Operator's Certification:
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used
Diameter of well bore to bottom of sealin.	and information reported above are true to my best knowledge and belief.
Diameter of well bore below sealin.	[Signed] Date 9-28, 1985
Number of sacks of cement used in well seal sacks How was cement grout placed?	Drilling Machine Operator's License No. 759
now was centered grout praced:	Water Well Contractor's Certification:
Alexanderector in Fig. 1. Alexanderector in	This well was drilled under my jurisdiction and this report is true to
Was pump installed?	the best of my knowledge and belief.
Was a drive shoe used? 🗆 Yes 🗀 No Plugs Size: location ft.	NameBigThreeDrilling & PumpService (Type or print)
Did any strata contain unusable water? Yes No	Address1990 NW 35th, Redmond, Or 97756
Type of Water? depth of strata	100 m / / / / / / / / / / / / / / / / / /
Method of sealing strata off	[Signed] (Water Vell Contractor)
Was well gravel packed? □ Yes ☑ No Size of gravel:	Contractor's License No. 685 Date 9-28 , 1985
1b. W	