

TEST SHEET

26/14-12C(1)
Lake Co

RECEIVED
OCT 21 1957
STATE ENGINEER
SALEM, OREGON

Owner,s Name Lonie

County Lake

Location T.W.s _____ R _____ Sec. _____

Size Hole 12 in. Depth 205 ft. Static Water Level 17 ft

Hours Pumped ~~#####~~

First hour 300 gal per. min. mostly sand Draw Down none

Second " " " " " Cleared up a little None

Third " " 350 None

Fourth 400 2 ft

Fifth 500 5 ft

Sixth 600 10 ft

Seventh 700 12 ft

Eight 775 Clear water 20 ft

26/14-12C(1)
LAKE CO.

Remark,s
Stoped pumping after eight hour,s
there seem,s to be plenty of water could
Speed pump up and it would held 1500 gal.
at 40ft. but lots of sand

Signed [Signature]

